



Thyro-A[®] Power Controller

Thyro-A ... H3 / HRL3 / HRLP3

User Manual

March 2025 57010153-00HB



Copyright

This manual and the information contained herein are the proprietary property of Advanced Energy Industries, Inc.

No part of this manual may be reproduced or copied without the express written permission of Advanced Energy Industries, Inc. Any unauthorized use of this manual or its contents is strictly prohibited. Copyright © 2016 - 2025 Advanced Energy Industries, Inc. All Rights Reserved.

Disclaimer and Limitation of Liability

The information contained in this manual is subject to change by Advanced Energy Industries, Inc. without prior notice. Advanced Energy Industries, Inc. makes no warranty of any kind whatsoever, either expressed or implied, with respect to the information contained herein. Advanced Energy Industries, Inc. shall not be liable in damages, of whatever kind, as a result of the reliance on or use of the information contained herein.

Product Usage Statement



WARNING:

Read this entire manual and all other publications pertaining to the work to be performed before installing, operating, or maintaining this equipment. Practice all plant and product safety instructions and precautions. Failure to follow instructions can cause personal injury and/or property damage. If the equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment might be impaired. All personnel who work with or who are exposed to this equipment must take precautions to protect themselves against serious or possibly fatal bodily injury.

Advanced Energy Industries, Inc. (AE) provides information on its products and associated hazards, but it assumes no responsibility for the after-sale operation of the equipment or the safety practices of the owner or user. NEVER DEFEAT INTERLOCKS OR GROUNDS.

**AVERTISSEMENT:**

Lire ce manuel au complet ainsi que toutes les autres publications portant sur le travail à effectuer avant d'installer, d'utiliser ou d'entretenir cet équipement. Suivre toutes les consignes de sécurité et appliquer toutes les mesures de précautions de l'usine et du produit. Ne pas suivre ces consignes peut entraîner des blessures corporelles et/ou des dommages matériels. Si l'équipement est utilisé de manière non spécifiée par le fabricant, la protection fournie par l'équipement peut être compromise. Tous les membres du personnel travaillant sur cet équipement ou qui y sont exposés doivent prendre des mesures de précaution pour se protéger contre des blessures graves, voire mortelles.

Advanced Energy Industries, Inc. (AE) fournit des renseignements sur ses produits et les dangers qui y sont liés, mais elle ne peut être tenue responsable du fonctionnement après-vente de l'équipement ou des pratiques de sécurité du propriétaire ou de l'utilisateur. **NE JAMAIS METTRE EN ÉCHEC OU CONTOURNER LES DISPOSITIFS DE PROTECTION DE VERROUILLAGE OU DE MISE À LA TERRE.**

Trademarks

All Advanced Energy trademarks are the property of Advanced Energy Industries, Inc. For the list of Advanced Energy trademarks, visit: <https://www.advancedenergy.com/legal/>. Any unauthorized use of Advanced Energy trademarks is prohibited.

All other trademarks are the property of their respective owners.

EtherCAT  is a registered trademark and patented technology, licensed by Beckhoff Automation GmbH, Germany.

Customer Feedback

Advanced Energy's technical writing staff has carefully developed this manual using research-based document design principles. However, improvement is ongoing, and the writing staff welcomes and appreciates customer feedback. Please send any comments on the content, organization, or format of this user manual to:

- tech.writing@aei.com

To order a manual, please contact Technical Support:

- Technical.Support@aei.com

Table of Contents

Chapter 1. Safety and Product Compliance Guidelines

Important Safety Information	1-1
Danger, Warning, and Caution Boxes	1-1
Safety Guidelines	1-2
Rules for Safe Installation and Operation	1-2
Interpreting Product Labels	1-2
Product Compliance	1-4
Product Certification	1-5
Safety and EMC Regulations, Directives, and Standards	1-5
EMC Testing	1-5
Conditions of Use	1-5
UL Markings and Requirements	1-6
Environmental Compliance	1-7
Interlocks and Limiting Conditions	1-8

Chapter 2. Product Overview

General Description	2-1
Unit Features	2-1

Chapter 3. Specifications

Physical Specifications	3-1
Electrical Specifications	3-4
Cooling Specifications	3-7
Environmental Specifications	3-9
Type Designation	3-10
Validity	3-10
Type Code	3-11

Chapter 4. Communication Controls

Controls and Indicators	4-1
Status Indicators (LEDs)	4-1
Relay Indicator	4-3
DIP Switch Settings	4-4
Potentiometer Settings	4-7
Setting Aids	4-8
Setting the Transformer Load	4-9
Setting Resistive Load	4-9

Setting Maximum Load Value With Control End U, U2 and P Control	4-11
Setting Maximum Load Value With Control End U, U2	4-12
Setting Maximum Load Current	4-12
Setting Example for Maximum Load Value at Control End / Maximum Load Current	4-13
Adapting Analog Output (Scale)	4-13
Setting Load Monitoring (Undercurrent Monitoring)	4-15
Analog and Digital I/O	4-16
Software User Interface	4-18

Chapter 5. Installation, Setup, and Operation

Preparing to Install the Unit	5-1
Spacing Requirements	5-1
Dimensional Drawings	5-1
Installation Requirements	5-15
Unpacking the Unit	5-16
Lifting the Unit	5-16
Installing the Unit	5-17
Mounting the Unit	5-17
Grounding	5-17
Connecting I/O and Auxiliary Connectors	5-17
Connecting Load and Auxiliary Power	5-18
Connection Diagrams	5-20
Installation as a Voltage Sequence Controller (VSC)	5-25
First Time Operation	5-28
Normal Operation	5-28
Operating Modes	5-29
Full-Wave Switch (TAKT)	5-29
Phase-Angle Firing (VAR)	5-29
Half-Wave Switch QTM (Quick TAKT Mode)	5-29
Switch Mode (SWITCH)	5-30
Setpoint Control	5-30
Switch Mode Setpoint	5-30
Control Types	5-31
Controlled Value	5-31
Control Characteristic Curves	5-32
Controller Response	5-33
Monitoring	5-33
Mains Voltage Monitoring	5-33
Device Temperature and Fan Monitoring	5-34
Monitoring Parallel Loads	5-34
Thyro-A 1A and Thyro-A 2A With Separate Star Point	5-35
Thyro-A 2A With Star and Delta Loads	5-36
Thyro-A 3A With Star and Delta Loads	5-38
Extended Functions	5-41
Extended Operating Modes/Circuit Types	5-41
Analog Output Averaging	5-42

Control Limits	5-42
Controller Parameters	5-42
Mains Load Optimization	5-42
Mains Load Optimization	5-43
Internal Mains Load Optimization	5-43
Synchronization With Optional Thyro-Power Manager Accessory	5-43
Basic Bus Module	5-44
Maintenance	5-44
Fan Maintenance	5-44

Chapter 6. Troubleshooting and Technical Support

Troubleshooting Checklist	6-1
Troubleshooting Checklist	6-4
Technical Support	6-5
Power Control Modules	6-6
Service, Repairs, and Upgrades	6-6
Obtaining an RMA Number Using an Existing MyAE Account	6-6
Obtaining an RMA Number Using the Online Form	6-6
Obtaining an RMA Number by Email	6-7
Obtaining an RMA Number by Telephone	6-7

List of Tables

Table 1-1. Transient surge suppression device ratings	1-6
Table 1-2. Interlocks and limiting conditions	1-8
Table 3-1. Physical specifications	3-1
Table 3-2. Type range 230 V, 400 V, 500 V	3-2
Table 3-3. Terminal size	3-3
Table 3-4. Electrical specifications	3-4
Table 3-5. Standard and extended voltage range	3-5
Table 3-6. Model-specific specifications	3-6
Table 3-7. Current derating	3-8
Table 3-8. Fan current, air volume, and sound pressure	3-8
Table 3-9. Environmental standard specifications	3-9
Table 3-10. Climatic specifications	3-9
Table 3-11. Type designation	3-11
Table 4-1. Thyro-A status LEDs	4-2
Table 4-2. LED blink codes	4-3
Table 4-3. S1 default settings	4-4
Table 4-4. Operating mode and load types	4-5
Table 4-5. Control mode/output scale	4-5
Table 4-6. Control mode	4-6
Table 4-7. Setpoint input range	4-6
Table 4-8. Analog output	4-7
Table 4-9. Potentiometer locations	4-8
Table 4-10. Setting aids	4-9
Table 4-11. Soft-start settings	4-10
Table 4-12. Maximum load value	4-11
Table 4-13. Maximum load current	4-13
Table 4-14. Analog output scaling for voltage and current	4-14
Table 4-15. Analog output scaling for power	4-14
Table 4-16. AC phase connection (X1)	4-17
Table 4-17. AC phase connection (X10) (present only on some 3-phase units)	4-17
Table 4-18. AC/DC auxiliary power input (X11)	4-17
Table 4-19. 11-pin analog I/O connector (X2)	4-17
Table 4-20. 7-pin bus module connector (X22)	4-18
Table 4-21. Relay K1 connectors (X3)	4-18
Table 5-1. Terminal screw size	5-20
Table 5-2. Terminal screw torque	5-20
Table 5-3. Control modes	5-31
Table 5-4. Response to load changes	5-33
Table 5-5. Limit values for mains voltage monitoring	5-34
Table 5-6. Load with separate star point and without neutral conductor	5-35
Table 5-7. Load with common star point and without neutral conductor	5-37
Table 5-8. Load in delta connection	5-38
Table 5-9. Load with common star point and without neutral conductor	5-38
Table 5-10. Load in delta connection	5-39

Table 5-11. Other possibilities of load monitoring 5-40

Table 6-1. Using LED states for troubleshooting 6-2

Table 6-2. Using LED states for troubleshooting 6-4

List of Figures

Figure 3-1. Current derating	3-8
Figure 4-1. Total setpoint	4-1
Figure 4-2. Status LEDs	4-2
Figure 4-3. DIP switch	4-4
Figure 4-4. Potentiometer locations	4-8
Figure 4-5. Front I/O connector	4-16
Figure 4-6. Bottom connectors	4-17
Figure 5-1. Thyro-A 1A 8 H, 16 H, 30 H	5-1
Figure 5-2. Thyro-A 1A 45 H, 60 H	5-2
Figure 5-3. Thyro-A 1A 100 H	5-2
Figure 5-4. Thyro-A 1A 130 H, 170 H	5-3
Figure 5-5. Thyro-A 1A 280 HF	5-3
Figure 5-6. Thyro-A 1A 350 HF	5-4
Figure 5-7. Thyro-A 1A 495 HF, 650 HF	5-4
Figure 5-8. Thyro-A 1A 495 HF, 650 HF C32	5-5
Figure 5-9. Thyro-A 1A 1000 HF, 1400 HF, 1500 HF	5-6
Figure 5-10. Thyro-A 2A 8 H, 16 H, 30 H	5-7
Figure 5-11. Thyro-A 2A 45 H, 60 H	5-7
Figure 5-12. Thyro-A 2A 100 H	5-8
Figure 5-13. Thyro-A 2A 130 H, 170 H	5-8
Figure 5-14. Thyro-A 2A 280 HF	5-9
Figure 5-15. Thyro-A 2A 350 HF	5-9
Figure 5-16. Thyro-A 2A 495 HF, 650 HF	5-10
Figure 5-17. Thyro-A 2A 1000 HF, 1400 HF, 1500 HF	5-10
Figure 5-18. Thyro-A 3A 8 H, 16 H, 30 H	5-11
Figure 5-19. Thyro-A 3A 45 H, 60 H	5-11
Figure 5-20. Thyro-A 3A 100 H	5-12
Figure 5-21. Thyro-A 3A 130 H, 170 H	5-12
Figure 5-22. Thyro-A 3A 280 HF	5-13
Figure 5-23. Thyro-A 3A 350 HF	5-13
Figure 5-24. Thyro-A 3A 495 HF, 650 HF	5-14
Figure 5-25. Thyro-A 3A 1000 HF, 1400 HF, 1500 HF	5-15
Figure 5-26. 1A power controller connections	5-22
Figure 5-27. 2A power controller connections	5-23
Figure 5-28. 3A power controller connections	5-24
Figure 5-29. Primary VSC	5-26
Figure 5-30. 2-phase as VSC 2	5-27
Figure 5-31. TAKT waveform	5-29
Figure 5-32. VAR waveform	5-29
Figure 5-33. QTM waveform	5-29
Figure 5-34. Setpoint inputs	5-30
Figure 5-35. U control	5-32
Figure 5-36. I control	5-32
Figure 5-37. P control	5-32
Figure 5-38. Load with separate star point and without neutral conductor	5-35

Figure 5-39. Load with common star point and without neutral conductor 5-36

Figure 5-40. Load in delta connection 5-37

Figure 5-41. Load with common star point and without neutral conductor 5-38

Figure 5-42. Load in delta connection 5-39

Figure 5-43. Other possibilities of load monitoring 5-40

Figure 5-44. Basic Bus Module 5-44

Safety and Product Compliance Guidelines

Important Safety Information

To ensure safe installation and operation of the Advanced Energy Thyro-A unit, read and understand this manual before attempting to install and operate this unit. At a minimum, read and follow the safety guidelines, instructions, and practices.

Danger, Warning, and Caution Boxes



This symbol represents important notes concerning potential harm to people, this unit, or associated equipment. Advanced Energy includes this symbol in danger, warning, and caution boxes to identify specific levels of hazard seriousness.



DANGER:

DANGER indicates an imminently hazardous situation that, if not avoided, will result in death or serious injury. DANGER is limited to the most extreme situations.



DANGER:

DANGER indique une situation dangereuse imminente qui, si elle n'est pas évitée, pourrait provoquer la mort ou des blessures graves. DANGER est réservé aux situations les plus extrêmes.



WARNING:

WARNING indicates a potentially hazardous situation that, if not avoided, could result in death or serious injury, and/or property damage.



AVERTISSEMENT:

AVERTISSEMENT indique une situation potentiellement dangereuse qui, si elle n'est pas évitée, pourrait provoquer la mort ou des blessures graves et/ou des dommages matériels.

**CAUTION:**

CAUTION indicates a potentially hazardous situation that, if not avoided, could result in minor or moderate injury, and/or property damage. CAUTION is also used for property-damage-only accidents.

**ATTENTION:**

ATTENTION indique une situation potentiellement dangereuse qui, si elle n'est pas évitée, pourrait provoquer des blessures mineures ou modérées et/ou des dommages matériels. ATTENTION est également utilisé pour des accidents causant uniquement des dommages matériels.

Safety Guidelines

Review the following information before attempting to install and operate the product.


Rules for Safe Installation and Operation

Please note the following rules:

- Do not attempt to install or operate this equipment without proper training.
- Ensure that this unit is properly grounded.
- Ensure that all cables are properly connected.
- Verify that input voltage and current source capacity are within specifications before turning on the unit.
- Use proper electrostatic discharge (ESD) precautions.
- Maintenance and service must be performed only by AE-trained service personnel.

Interpreting Product Labels

The following labels might appear on the unit:



Capacitor discharge warning (5 minutes)



CE label

or



Complies with applicable European directives.



UK Conformity Assessed label

Complies with applicable United Kingdom regulations.



Protective conductor terminal



On or off




Phase

or



Power on/standby



Hazardous voltage



Hazardous voltage

Voltage > 30 V_{RMS}, 42.4 V_{peak}, or 60 V DC



Hot surface



No user-serviceable parts



European Union RoHS compliant



Refer to manual for more information

or



Short-circuit protected



Environmentally Friendly Use Period of 25 years per China RoHS—recycle responsibly at end of life




Electrocution hazard



Heavy object—can cause muscle strain or back injury



Heavy object—do not lift manually



Electrical fuse



Alternating current



Direct current



UL® Listed to Canadian and United States safety standards



UL Listed to United States safety standards



UL Recognized to Canadian and United States safety standards



UL Recognized to United States safety standards

Product Compliance

The following sections include information about unit compliance and certification, including the conditions of use required to be in compliance with the standards and directives.

Product Certification

Certain options of this product may be certified according to the list below.

For more information, refer to the Certificate or Letter of Conformity (US) or Declaration of Conformity (EU), available on request.

- CE Marking – Self-declaration, assessed by AE Corporate Compliance
- EMC measurements – Verified by AE Corporate Compliance
- UL registration file E135074 according to UL 508

Safety and EMC Regulations, Directives, and Standards

For information concerning compliance to applicable EU requirements, refer to the EU Declaration of Conformity shipped with this unit. For information concerning compliance to applicable UK requirements, refer to the UK Declaration of Conformity for this unit. The Declaration of Conformity might also include a supplementary section covering compliance to other regulatory requirements and/or industry standards or guidelines.

EMC Testing

EMC testing was performed on Thyro-A units with the operating mode set to burst-firing. Thyro-A units are also delivered in burst-firing mode.

If the operating mode is changed to phase-angle firing, the line-related noise might exceed EMC regulations. If the line-related noise exceeds EMC regulations, implement measures to ensure that line-related noise is within the limits set by EMC regulations. Collect the line-related noise values while operating the entire system. Measuring line-related noise while operating a single Thyro-A unit might not provide true noise values.

Conditions of Use

Comply with the stated directives and standards by meeting the following conditions of use:

- Before making any other connection to this product, connect the primary Protective Earth (ground), and secondary Protective Earth (ground) if applicable, to a local earth ground using wire that is sized according to the applicable requirements.
- Install and operate this unit in an overvoltage category according to environmental specifications.
- Install and operate this unit with a dedicated circuit breaker on the AC input. The circuit breaker must be easily accessible and near the unit. The circuit breaker must be marked as the disconnecting device for the equipment.
- Use only a shielded cable for communications and/or control connections.

- Limit the system load current to the maximum specified level for the unit.
- Dispose of this product as directed by applicable laws and regulations.
- For the input and output power connections, use wires that are suitable for at least 75°C (167°F).
- Do not allow condensation of any liquids or accumulation of conductive dust on the instrument. Doing so will have unpredictable results, possibly including, but not limited to, loss of accuracy.

UL Markings and Requirements

To use the unit under UL conditions, you must comply with the following additional conditions of use:

- Make electrical connections following the specified tightening torque. See [“Connecting Load and Auxiliary Power”](#) on page 5-18.
- Use 60°C, 60°C/75°C, or 75°C copper conductors, as specified by model. See [Table 3-3](#) on page 3-3.
- The maximum surrounding air temperature under UL conditions is 40°C (104°F).
- The unit is suitable for use on a circuit capable of delivering not more than 100 kA RMS symmetrical amperes, xxx volts maximum, when protected by RK5 class fuses, where xxx is the maximum rated voltage of the unit.
- Branch circuit protection must be provided and sized according to National Electrical Code® and any additional local codes.
- The 24 V power supply for terminal (X7) needs to be protected by a cULus-listed fuse, rated maximum 4 A and minimum 50 V DC.
- The unit is suitable for use in Pollution Degree 2 environment.

For installations according to Canadian National Standard C22.2 No. 14-13 (cUL Mark only):

Transient surge suppression devices shall be installed on the line side of this equipment and shall be rated ___ (phase to ground), ___ V (phase to phase), suitable for overvoltage category III, and shall provide protection for a rated impulse withstand voltage peak of ___ kV, as shown in the following table.

Table 1-1. Transient surge suppression device ratings

Supply Voltage	Phase to Ground Voltage	Phase to Phase Voltage	Impulse Withstand Voltage Peak
Corner Ground Sources			
115 V	120 V	120 V	2.5 kV
230 V	230 V	230 V	4 kV
400 V	400 V	400 V	6 kV

Table 1-1. Transient surge suppression device ratings (Continued)

Supply Voltage	Phase to Ground Voltage	Phase to Phase Voltage	Impulse Withstand Voltage Peak
500 V	500 V	500 V	6 kV
Grounded Wye Sources			
115 V	70 V	120 V	1.5 kV
230 V	133 V	230 V	2.5 kV
400 V	230 V	400 V	4 kV
500 V	288 V	500 V	4 kV

Environmental Compliance

- **EU RoHS – European Union Directive 2011/65/EU (RoHS 2)**

Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment

This product is EU 2011/65/EU (RoHS 2) compliant, designed to contain no more than the maximum concentration of hazardous substances listed in Annex II, with possible exemptions from Annex III or IV. Because this product is installed as a component in a large-scale fixed installation or stationary industrial tool: the product is outside the scope of this Directive, compliance is not required, and the EU RoHS Directive is not declared on the CE Declaration of Conformity.

European Delegated Directive (EU) 2015/863 (RoHS 3) – Amendment to Annex II of Directive 2011/65/EU (RoHS 2) Regarding the List of Restricted Substances

This product is also compliant to the 2015/863 amendment, containing no more than the maximum concentration of four additional hazardous substances (phthalates) listed in amended Annex II.

- **EU REACH – European Union Regulation (EC) No. 1907/2006**

Registration, Evaluation, Authorization and Restriction of Chemicals

Advanced Energy manufactures articles subject to Article 33 of REACH and, upon request, will provide information regarding Substances of Very High Concern (SVHC) currently identified by the European Chemical Agency (ECHA) that are contained in this product, at concentrations greater than 0.1% by weight.

- **China RoHS – People’s Republic of China (PRC) Ministry of Industry and Information Technology (MIIT) Order #32 (China RoHS 2)**

Management Methods for the Restriction of the Use of Hazardous Substances Electrical and Electronic Products

This product contains hazardous substances listed in PRC Standard GB/T 26572, above the maximum concentration limits stipulated. In compliance to PRC Standard SJ/T 11364, AE provides a disclosure of hazardous substance content and this product is marked with an Environmentally Friendly Use Period (EFUP) of 25 years.

Interlocks and Limiting Conditions



WARNING:

Advanced Energy products only include interlocks when required by product specification. Interlocks in Advanced Energy products are not intended to meet or satisfy safety requirements. Where interlocks exist, you must still meet and satisfy safety requirements. The presence of interlocks does not imply operator protection.



AVERTISSEMENT:

Les produits Advanced Energy comprennent des dispositifs de verrouillage uniquement si la spécification du produit l'exige. Les dispositifs de verrouillage d'Advanced Energy ne sont pas destinés à satisfaire aux normes de sécurité ni à s'y conformer. Lorsqu'un système comprend un dispositif de verrouillage, vous demeurez responsable de satisfaire aux normes de sécurité et de vous y conformer. La présence d'un dispositif de verrouillage n'implique pas la protection de l'opérateur.

Table 1-2. Interlocks and limiting conditions

Mechanism	Detection Method	Equipment Condition When Interlock is Open
By opening the <i>PULSE LOCK</i> jumper the unit is locked.	Opening the <i>PULSE LOCK</i> jumper or external interlock circuit Terminal X2.1 connected to terminal X2.2	The red PULSE LOCK LED on the front panel is blinking. The output is disabled.

The interlock jumper can be removed and replaced with an external interlock circuit capable of switching 24 V, 20 mA.

Product Overview

General Description

The Thyro-A power controller is a communication-capable thyristor power controller. Use the Thyro-A power controller wherever control of alternating voltages, alternating currents, or outputs in thermal process technology is required. The Thyro-A power controller has several different control and regulation modes, can easily be connected to process and automation technology, has a high degree of control accuracy, and is simple to handle.

Unit Features

The Thyro-A unit offers several features for improved handling and operation:

- Integrated semiconductor fuse
- Type range 230 V to 500 V, 8 A to 1500 A, 1-phase, 2-phase, and 3-phase
- Resistive load and transformer load in operating mode VAR
- Soft start function for transformer load
- Channel separation, necessary with countervoltage
- Control modes U, U²
- Operating modes TAKT, VAR
- Operating mode QTM (with Thyro-A 1A)
- Synchronization option, available for the following operating modes:
 - TAKT with optional Thyro-Power Manager
 - QTM with internal mains load optimization
- Control with analog setpoint, via PC using optional Thyro-Tool Pro software, or with an optional bus module
- Micro USB system interface
- Safe isolation in accordance with EN 62477-1

Units with type designations HRL3 and HRLP3 have these additional features:

- External auxiliary power supply input, allowing operation with mains voltages up to $0.43 \times U_{\text{nom}}$
- Load with high $R_{\text{warm}}/R_{\text{cold}} (\leq 6)$, peak current limitation of $3 \times I_{\text{nom}}$
- Load current monitoring

- Signaling relay
- Analog output
- Control modes I, I²

Units with type designations HRLP3 have this additional feature:

- Control mode P

Options include:

- Thyro-Tool Pro computer user interface
- Bus connection via bus adapters for:
 - PROFIBUS®
 - PROFINET®
 - Ethernet/IP™
 - EtherCAT®
 - Other bus systems on request

Specifications

Physical Specifications

Table 3-1. Physical specifications

Description	Specification
General Physical Specifications	
Size	See Table 3-2
Weight	
Mounting	
Mechanical	Mounting hardware not included
Connectors	
AC phase connection (X1)	Included 2-pin plug-in screw terminal block, 0.2 mm ² - 2.5 mm ² (24 AWG - 12 AWG)
USB X5	µUSB (connector and cable not included)
Analog I/O (X2)	Included 11-pin, plug-in, screw terminal block, 0.14 mm ² - 1.5 mm ² (30 AWG - 14 AWG)
24 V AC or 24 V DC auxiliary power input (X11) [1]	Included 2-pin, plug-in, screw terminal block, 0.14 mm ² - 1.5 mm ² (30 AWG - 14 AWG)
Relay K1 (X3)	Included 3-pin, plug-in, screw terminal block, 0.14 mm ² - 1.5 mm ² (30 AWG - 14 AWG)
Bus module (X22)	Included 7-pin, plug-in, screw terminal block, 0.14 mm ² - 1.5 mm ² (30 AWG - 14 AWG)
Degree of protection	IP10
¹ Type HRL3 and HRLP3 only.	

Table 3-2. Type range 230 V, 400 V, 500 V

Model	Dimensions (WxHxD)			Weight	Dimensional
Type Current (A)	mm (in)			kg (lb)	Drawing
Thyro-A 1A					
8, 16, 30	45 (1.76)	136 (5.35)	129 (5.08)	0.7 (1.5)	Figure 5-1
45, 60	52 (2.0)	203 (8.0)	184 (7.3)	1.7 (3.7)	Figure 5-2
100	75 (3.0)	203 (8.0)	193 (7.6)	1.7 (3.7)	Figure 5-3
130, 170	125 (4.9)	320 (12.6)	241 (9.5)	4 (8.8)	Figure 5-4
280	125 (4.9)	370 (14.6)	241 (9.5)	5 (11.0)	Figure 5-5
350	125 (4.9)	400 (15.8)	261 (10.3)	8.4 (18.5)	Figure 5-6
495, 650	112 (4.4)	414 (16.3)	344 (13.5)	15 (33.1)	Figure 5-7
495, 650 C32	112 (4.4)	414 (16.3)	344 (13.5)	15 (33.1)	Figure 5-8
1000, 1400, 1500	239 (9.4)	729 (28.7)	516 (20.3)	35 (77.2)	Figure 5-9
Thyro-A 2A					
8, 16, 30	89 (3.5)	136 (5.4)	129 (5.1)	1.4 (3.1)	Figure 5-10
45, 60	104 (4.1)	203 (8.0)	184 (7.3)	3.4 (7.5)	Figure 5-11
100	150 (5.9)	203 (8.0)	193 (7.6)	3.8 (8.4)	Figure 5-12
130, 170	250 (9.8)	320 (12.6)	241 (9.5)	8 (17.6)	Figure 5-13
280	250 (9.8)	393 (15.5)	241 (9.5)	11 (24.3)	Figure 5-14
350	250 (9.8)	430 (16.9)	261 (10.3)	16.7 (36.8)	Figure 5-15
495, 650	194 (7.6)	380 (15.0)	345 (13.6)	22 (48.5)	Figure 5-16
1000, 1400, 1500	417 (16.4)	685 (27.0)	516 (20.3)	54 (119.0)	Figure 5-17
Thyro-A 3A					
8, 16, 30	135 (5.3)	136 (5.4)	129 (5.1)	2.1 (4.6)	Figure 5-18
45, 60	156 (6.1)	203 (8.0)	184 (7.3)	5.1 (11.2)	Figure 5-19
100	225 (8.9)	203 (8.0)	193 (7.6)	5.7 (12.5)	Figure 5-20
130, 170	375 (14.8)	320 (12.6)	241 (9.5)	12 (26.5)	Figure 5-21
280	375 (14.8)	393 (15.5)	241 (9.5)	15 (33.1)	Figure 5-22
350	375 (14.8)	430 (16.9)	261 (10.3)	25.5 (56.2)	Figure 5-23
495, 650	276 (10.9)	380 (15.0)	345 (13.6)	30 (66.1)	Figure 5-24
1000, 1400, 1500	583 (23.0)	685 (27.0)	516 (20.3)	74 (163.1)	Figure 5-25

Unless otherwise noted in the following table, use 60°C (140°F) or 60°C (140°F)/75°C (167°F) copper conductors in UL applications.

Table 3-3. Terminal size

Type Current	AC Connection Screw Size	Ground Screw Size	Conductor Area	Wire Gauge
8 A, 16 A, 30 A	Lug or M4	Lug or M4	6 mm ²	10 AWG
45 A ^[1] 60 A ^[1] , 100 A ^[1]	M6	M6 maximum	50 mm ²	0 (1/0) AWG
130 A, 170 A	M8	M10	95/120 mm ²	0000 (4/0) AWG
280 A	M10	M10	150/185 mm ²	
350 A	M10	M10	185 mm ²	
495 A	M10	M10	Cu 48x3 Two 11 mm holes	
650 A	M10	M10	Cu 48x3 Two 11 mm holes	
1000 A	M12	M12	Cu 60x10 Two 14 mm holes	
1400 A	M12	M12	Cu 60x10 Two 14 mm holes	
1500 A	M12	M12	Cu 60x10 Two 14 mm holes	
¹ In UL applications, use only 75°C copper conductors (except for control circuits).				

Electrical Specifications

Table 3-4. Electrical specifications

Description	Specification
Electrical Requirements	
AC input voltage	Type H3: 230 V, 400 V, 500 V, -57% to +10% ^[1] See Table 3-5 .
	Type HRL3, HRLP3: 230 V, 400 V, 500 V, -15% to +10% Extended range -57% to +10% (with separate 24 V auxiliary power supply) See Table 3-5 .
Auxiliary power supply input ^[2]	24 V AC +10% /-20% 24 V DC +18 V to +32 V The auxiliary voltage supply can be AC or DC (2 W per device/5 VA/not grounded)
Fan input voltage (type designation F)	230 V, 50/60 Hz, 115 V fans are available as a special order for some units. For fan current and current derating see “ Cooling Specifications ” on page 3-7
AC line frequency	50/60 Hz nominal; 47 Hz to 63 Hz range
AC current	See Table 3-6 .
Rated power	
Dissipation	
Semiconductor fuse	
Ground connection	Chassis ground near AC connector suitable for ring lug connection
Load description	Resistive load (minimum 100 W)
	Resistive load $R_{\text{warm}}/R_{\text{cold}}$ ratio up to 6
	Transformer load
External transformer	The induction of the load side transformer should not exceed 1.45T in case of mains overvoltage when using grain-oriented, cold-rolled plates. This corresponds to a nominal induction of approximately 1.3T.
Setpoint inputs	0(4) mA - 20 mA $R_i = 250 \Omega$ / max 24 mA. The maximum open-circuit voltage = 24 V.

Table 3-4. Electrical specifications (Continued)

Description	Specification
	0(1) V - 5 V $R_i = 44 \text{ k}\Omega$ / max 12 V 0(2) V - 10 V $R_i = 88 \text{ k}\Omega$ / max 12 V
Analog outputs ^[2]	Signal level 0 V - 10 V, 0 mA - 20 mA, or 4 mA - 20 mA with $R_{\min}$ of 500 Ω . The maximum burden voltage is 10 V.
Precision	U-Control: Better than $\pm 1.5\%$ (only valid from -15% to +10% of the type voltage) I-Control: $\pm 1.5\%$ P-Control: Better than $\pm 3\%$ ^[3] All specifications are relating to the respective final value.
Limitations	Voltage limitation U_{RMS} Current limitation $I_{\text{RMS}} = \text{default setting}$ Effective power limitation P Peak current limitation
Relay ^[2]	AC max: 250 V/6 A (1500 VA) AC min: >10 VA DC max: 300 V/0.25 A (62.5 W) DC min: 5 V/20 mA Contact material: AgCdO With UL applications AC max: 250 V/4 A
¹ The X2.8 setpoint potentiometer power supply on type H3 units can be used only when the AC input voltage is within the -15% to +10% range. ² Type HRL3 and HRLP3 only. ³ Type HRLP3 only.	

Table 3-5. Standard and extended voltage range

Type Voltage	Range	Voltage Range
Thyro-A H3 ^[1]		
230 V	-57% to +10%	99 V < U mains $\leq$ 253 V
400 V	-57% to +10%	172 V < U mains $\leq$ 440 V
500 V	-57% to +10%	215 V < U mains $\leq$ 550 V
Thyro-A HRL3, HRLP3		
230 V	-15% to +10%	196 V < U mains $\leq$ 253 V

Table 3-5. Standard and extended voltage range (Continued)

Type Voltage	Range	Voltage Range
400 V	-15% to +10%	340 V < U mains ≤ 440 V
500 V	-15% to +10%	425 V < U mains ≤ 550 V
Thyro-A HRL3, HRLP3 with external 24 V auxiliary power supply		
230 V	-57% to +10%	99 V < U mains ≤ 253 V
400 V	-57% to +10%	172 V < U mains ≤ 440 V
500 V	-57% to +10%	215 V < U mains ≤ 550 V
¹ The X2.8 setpoint potentiometer power supply on type H3 units can be used only when the AC input voltage is within the -15% to +10% range.		

Table 3-6. Model-specific specifications

Current (A)	Type Power (kW)			Dissipation (W)	Fuse (A)
	230 V	400 V	500 V		
Thyro-A 1A ... H3, ... HRLP3					
8	3.2	3.2	4	9	10
16	3.7	6.4	8	30	20
30	6.9	12	15	47	40
45	10	18	22.5	52	63
60	14	24	30	80	80
100	23	40	50	105	200
130	30	52	65	150	200
170	39	68	85	210	315
280	64	112	140	330	350
350	80	140	175	390	500
495		198	247	603	630
650		260	325	726	900
1000		400	500	1396	2x100
1400			700	1715	4x900
1500		600		1755	4x900
Thyro-A 2A ... H3, ... HRLP3					
8		6	7	18	10
16		11	14	60	20
30		21	26	94	40
45		31	39	96	63
60		42	52	160	80

Table 3-6. Model-specific specifications (Continued)


Current (A)	Type Power (kW)			Dissipation (W)	Fuse (A)
	230 V	400 V	500 V		
100		69	87	210	200
130		90	112	300	200
170		118	147	420	315
280		194	242	660	350
350		242	303	780	500
495		343	429	1206	630
650		450	563	1453	900
1000		693	866	2811	2x1000
1400			1212	3451	4x900
1500		1039		3510	4x900
Thyro-A 3A ... H3, ... HRLP3					
8		6	7	27	10
16		11	14	90	20
30		21	26	141	40
45		31	39	144	63
60		42	52	240	80
100		69	87	315	200
130		90	112	450	200
170		118	147	630	315
280		194	242	990	350
350		242	303	1170	500
495		343	429	1822	630
650		450	563	2192	900
1000		693	866	4127	2x1000
1400			1212	5086	4x900
1500		1039		5206	4x900

Cooling Specifications

Type H Thyro-A power controllers are self cooled, while type HF units are force cooled. The fan in HF units require a separate power source at 230 V, 50/60 Hz. A 115 V fan is available by special-order for some units.

Table 3-7. Current derating

Air Temperature	I/I _{RATED} CURRENT (A)	
	Self Cooling	Forced Cooling
0°C to +25°C (32°F to 77°F)	1.10	1.10
30°C (86°F)	1.10	1.05
35°C (95°F)	1.10	1.00
40°C (104°F)	1.05	0.96
45°C (113°F)	1.00	0.91
50°C (122°F)	0.95	0.87
55°C (131°F)	0.88	0.81
UL applications limited to +40°C (104°F)		

**Figure 3-1. Current derating****Table 3-8. Fan current, air volume, and sound pressure**

Model	Current (A) ^[1]		Air Volume (m³/h)	Sound Pressure (dbA @ 1 m)
	50 Hz	60 Hz		
1A				
280 F, 350 F	0.22	0.22	120	67
495 F, 650 F C32 Variance ^[2]	22 W at 115/230 V, 50/60 Hz		288	58
1000 F, 1400 F, 1500 F	0.29	0.35	880	58

Table 3-8. Fan current, air volume, and sound pressure (Continued)

Model	Current (A) ^{1/}		Air Volume (m³/h)	Sound Pressure (dbA @ 1 m)
	50 Hz	60 Hz		
2A				
280 F, 350 F	0.5	0.38	200	70
495 F, 650 F	0.31	0.25	380	49
1000 F, 1400 F, 1500 F	0.56	0.79	1970	70
3A				
280 F, 350 F	0.5	0.38	260	70
495 F, 650 F	0.29	0.35	880	58
1000 F, 1400 F, 1500 F	0.56	0.79	1970	70
¹ For 230 V fans.				
² For 24 V DC fans.				

Environmental Specifications

The two following tables describe the environmental specifications for the Thyro-A unit.

Table 3-9. Environmental standard specifications

Description	Specification
Overvoltage	Category III per IEC 62477-1
Pollution degree	2

Table 3-10. Climatic specifications

	Temperature	Relative Humidity	Air Pressure
Operating	Self cooled models:	5% to 85% ^[1]	89.9 kPa to 106 kPa
	+0°C to +45°C	1 g/m³ to 25 g/m³	899 mbar to 1060 mbar
	+32°F to +113°F	1 g/m³ to 25 g/m³	
	Force cooled models:		Equivalent altitude: +1000 m to –500 m (+3281' to –1640') ^[2]
	+0°C to +35°C		
	+32°F to +95°F		

Table 3-10. Climatic specifications (Continued)

	Temperature	Relative Humidity	Air Pressure
Storage	–25°C to +55°C –13°F to +131°F	5% to 95% 1 g/m ³ to 29 g/m ³	78.8 kPa to 106 kPa 788 mbar to 1060 mbar Equivalent altitude: +2000 m to –500 m (+6562' to –1640')
Transportation	–25°C to +70°C –13°F to +158°F	95% ^[3] 60 g/m ³ ^[4]	65.6 kPa to 106 kPa 656 mbar to 1060 mbar Equivalent altitude: +3500 m to –500 m (+11480' to –1640')
¹ Non-condensing, no formation of ice ² Operation at higher altitudes is possible with reduced current limits. From +1000 m to +2000 m (+3281' to +6562'), the rated current is decreased by 1.5%/100 m (1.5%/328'). Contact AE Technical Support for operating at >+2000 m (+6562'). ³ Maximum relative humidity when the unit temperature slowly increases, or when the unit temperature directly increases from –25°C to +30°C (–13°F to +86°F) ⁴ Maximum absolute humidity when the unit temperature directly decreases from +70°C to +15°C (+158°F to +59°F)			

Type Designation

Validity

This manual describes the Thyro-A power controller series versions ... H3, ... HRL3, and ... HRLP3. Product characteristics that are only provided by the Thyro-A ... HRL3 and ... HRLP3 series are marked in the text.

These operating instructions comply with the current technical specifications of the device at the time of publication. The contents do not constitute a subject matter of the contract, but serve for information purposes only.

AE reserves the right to alter any specifications given in this manual, especially with regard to technical data, operation, weights, and dimensions. Advanced Energy reserves the right to make modifications with regard to the content and technical data in these operating instructions.

Type Code

The type designation of the thyristor-power controller is derived from the configuration of the power unit as well as from other features.

Thyro-A 1A

Thyristor controller with 1-phase power unit, suited for 1-phase loads in operating modes TAKT, VAR, and QTM.

Thyro-A 2A

Thyristor controller with 2-phase power unit, suited for symmetrical loads in 3-phase operation in 3-phase economical circuit in operating mode TAKT. The unit calculates the values of load current on phase L2, based on the measured values of phase L1 and L3.

Thyro-A 3A

Thyristor controller with 3-phase power unit, suited for 3-phase loads in operating modes TAKT and VAR.

Table 3-11. Type designation

Type range	Designation	Features
Thyro-A	1A	1-phase power section, for 1-phase operation
	2A	2-phase power section used with a 3-phase load in 3-phase economic circuit (not for phase-angle firing VAR)
	3A	3-phase power section, for 3-phase operation
	... 400-	With 400 V type voltage
	... 280	With 280 A type current
	H	With integrated semiconductor fuse
	F	With fan
	R	With signaling relay
	L	With load monitoring
	P	With power measurement and control
	3	Upgraded Thyro-A series

Thyro-A ... H3

Thyristor power controller with integrated semiconductor fuse, system bus interface, synchronization option, and control modes U, U². The power controller is suitable for visualization and commissioning software using the Thyro-Tool Pro software.

Thyro-A ... HRL3

Thyristor power controller with integrated semiconductor fuse, system bus interface, additional 24 V DC/V AC electronic power supply, signaling relay, load monitoring

and analog output, channel separation, synchronization option, control modes U, U^2 , I, I^2 . The power controller is suitable for visualization and commissioning software using the Thyro-Tool Pro software.

Thyro-A ... HRLP3

Thyristor power controller with integrated semiconductor fuse, system bus interface, additional 24 V DC/V AC electronic power supply, signaling relay, load monitoring and analog output, channel separation, synchronization option, and control modes U, U^2 , I, I^2 , and P. The power controller is suitable for visualization and commissioning software using the Thyro-Tool Pro software.

Communication Controls

Controls and Indicators

You can configure the Thyro-A using either the internal DIP switches or the Thyro-Tool Pro software.

Easily adapt the setpoint control characteristics of the Thyro-A power controller for the control output signal of the upstream process controller or automation system. The adaptation is made by changing the starting and ending points of the control characteristic. Inverted operation (ending value is smaller than the starting value in voltage or current) is also possible.

- Setpoint 1: (X2.4 to X2.3 ground) 0 mA to 20 mA default, configurable as 4 mA to 20 mA, 0(1) V to 5 V, or 0(2) V to 10 V
- Setpoint 2: Setpoint of the superordinate system or PC via either USB or the optional bus interface




Figure 4-1. Total setpoint

The setpoint input is selected by configuring terminal X22.1. Setpoint 2 is selected when X22.1 is grounded, setpoint 1 is selected when X22.1 is ungrounded.

Status Indicators (LEDs)

The Thyro-A unit LED status indicators are located on the front panel of the unit.




Figure 4-2. Status LEDs

Table 4-1. Thyro-A status LEDs

LED	Status
ON / READY	Amber: On, ready for operation Red: On, not ready for operation, check other LEDs Off: No power, hardware fault
LIMIT / 100%	Red blinking: Limitation is active, see following table Green: Output is at 100% Amber fast blinking: Setting aid active, parameter is at 100%
PULSE LOCK / 80%	Red blinking: Pulse lock active, see following table Green: Output is at 80% Amber fast blinking: Setting aid active, parameter is at 80%
FAULT / 60%	Red blinking: Fault present, see following table Green: Output is at 60% Amber fast blinking: Setting aid active, parameter is at 60%
LOAD FAULT / 40%	Red blinking: Load fault, see following table Green: Output is at 40% Amber fast blinking: Setting aid active, parameter is at 40%
MAINS / 20%	Red blinking: Mains fault, see following table Green: Output is at 20% Amber fast blinking: Setting aid active, parameter is at 20%

Red fault LEDs also signal the type of fault using a blink code, as shown in the following table.

Table 4-2. LED blink codes

Fault LED	Blink Number			
	1	2	3	4
LIMIT / 100%	Voltage limit	Current limit	Power limit	
PULSE LOCK / 80%	Jumper open, or other condition causing pulse lock			
FAULT / 60%	Main/Satellite fault	Flash memory fault or configuration fault	Temperature fault	Thyristor short circuit
LOAD FAULT / 40%	Load voltage out of limits	Load current out of limits	Load power out of limits	Load fault
MAINS / 20%	Overvoltage	Undervoltage	Phase sequence/phase fault	Frequency/sync

Relay Indicator

Errors and faults are indicated by the status LEDs, the optional fault and limit relay, and the optional bus interface. The presence of the optional relay is indicated by the letter **R** in the type code.

The unit signals faults in the power controller or load circuit via the **FAULT** LED and fault relay K1. To identify the location of the fault, check the LED blink code, or check the fault register using the bus interface.

Important

This manual describes the default configuration. Though these functions are fully configurable, AE recommends not changing the default configuration.

Fault signaling relay K1 has a changeover contact. Messages that cause the fault signaling relay to switch can be set with Thyro-Tool Pro software. In the default state, fault signaling relay K1 functions on the closed circuit principle.

In the event of the following errors, the fault signaling relay de-energizes and the power controller switches off:

- SYNC error
- Internal error
- Undervoltage in the mains
- Main/Satellite error

- Error rotating field/phase
- Overtemperature

In the event of the following error, the fault signaling relay de-energizes, the power controller remains on, and the **LOAD FAULT** LED blinks:

- Undercurrent in the load circuit

DIP Switch Settings

There is a 10-pin DIP switch behind the cover of the Main power unit for device configuration. The DIP switch is only read in once by the control device at switch-on or when the mains returns. Before commissioning, the DIP switch must be set to suit the application.

- Switch off mains supply and secure against accidentally being switched back on.
- Remove the cover of the Main power unit.
- Set configuration on the DIP switch.




Figure 4-3. DIP switch

Table 4-3. S1 default settings

Type	1	2	3	4	5	6	7	8	9	10	Function
1A ... H3/HRL3 and 2A ... H3/HRL3											
	1	0									TAKT operating mode
			0	0	0						UxU control mode
						0					0 mA live zero setpoint
							1	1			0 mA to 20 mA setpoint input
									0		Live zero analog output (HRL3 only)
										1	Analog output 10 V (HRL3 only)
1A ... HRLP3 and 2A ... HRLP3											
	1	0									TAKT operating mode
			1	0	1						P control mode
						0					0 mA live zero setpoint
							1	1			0 mA to 20 mA setpoint input

Table 4-3. S1 default settings (Continued)

Type	1	2	3	4	5	6	7	8	9	10	Function
									0		Live zero analog output
										1	Analog output 10 V
3A ... H3/HRL3/HRLP3											
	0	1									VAR operating mode
			0	0	0						UxU control mode
						0					0 mA live zero setpoint
							1	1			0 mA to 20 mA setpoint input
									0		Live zero analog output (HRL3, HRLP3)
										1	Analog output 10 V

Table 4-4. Operating mode and load types

Type	1	2	3	4	5	6	7	8	9	10	Function
1A and 2A											
Default	1	0	0	0	0	0	1	1	0	1	TAKT, UxU, Transformer load, 0 mA to 20 mA setpoint, 0 V to 10 V analog output
	1	0									TAKT
	0	1									VAR (1A only)
	1	1									QMT (1A only)
3A											
Default	0	1	0	0	0	0	1	1	0	1	VAR, UxU, Transformer load, 0 mA to 20 mA setpoint, 0 V to 10 V analog output
	0	1									VAR with delta or star without neutral conductor
	1	1									VAR with star with neutral conductor
	0	0									VAR with open delta
	1	0									TAKT with delta or star without neutral conductor
	Can be set with Thyro-Tool Pro software.										TAKT with delta or star with neutral conductor
											TAKT with open delta

Table 4-5. Control mode/output scale

Type	1	2	3	4	5	6	7	8	9	10	Function	R201 Function ^[1]
H3												
			0	0	0						UxU	Transformer load (phase angle 1st half-wave)
			0	0	1						UxU with Umax	Uload max

Table 4-5. Control mode/output scale (Continued)

Type	1	2	3	4	5	6	7	8	9	10	Function	R201 Function ^[1]
			1	0	0						U	Transformer load (phase angle 1st half-wave)
			1	0	1						U with Umax	Uload max

¹ When DIP switch S1.5 is at **ON**, the maximum load voltage (with U/U² control) can be defined on potentiometer R201. See “[Setting Maximum Load Value With Control End U, U²](#)” on page 4-12.

Table 4-6. Control mode

Type	1	2	3	4	5	6	7	8	9	10	Function
HRL3/HRLP3											
			0	0	0						UxU with analog output Uload
			1	0	0						U with analog output Uload
			0	1	0						IxI with analog output Iload
			1	1	0						I with analog output Iload
			0	0	1						I with analog output Uload
			1	0	1						UxU with analog output Iload only for HRL3
			0	1	1						U with analog output Iload only for HRL3
HRLP3											
			1	0	1						P with analog output Pload
			0	1	1						P with analog output Iload
H3/HRL3/HRLP3											
			1	1	1						Thyro-Tool Pro software mode

The highest value of the load voltage or load current is always used for control and display. The total power is used for power control. If a bus module or PC is connected, control mode and analog output can be set separately, for example, U control with I display.

Table 4-7. Setpoint input range

Type	1	2	3	4	5	6	7	8	9	10	Function
Setpoint H3/HRL3/HRLP3											
						0	1	1			0 mA to 20 mA setpoint (Ri=250 Ω)
						1	1	1			4 mA to 20 mA setpoint (Ri=250 Ω)
						0	0	1			0 V to 5 V setpoint (Ri=44 Ω)
						1	0	1			1 V to 5 V setpoint (Ri=44 Ω)
						0	0	0			0 V to 10 V setpoint (Ri=88 Ω)

Table 4-7. Setpoint input range (Continued)

Type	1	2	3	4	5	6	7	8	9	10	Function
						1	0	0			2 V to 10 V setpoint ($R_i=88\ \Omega$)

The analog input can be adapted to the various process controllers with the setpoint and live zero switches. The +5 V supply voltage can be taken from terminal X2.8 for a setpoint potentiometer ($5\ \text{k}\Omega < R < 10\ \text{k}\Omega$).

Table 4-8. Analog output

Type	1	2	3	4	5	6	7	8	9	10	Function
HRL3/HRLP3											
									0	1	0 V to 10 V analog output
									1	1	2 V to 10 V analog output
									0	0	0 mA to 20 mA analog output
									1	0	4 mA to 20 mA analog output

The analog output allows the effective values U_{load} , I_{load} , or P (HRLP3) to be displayed. The output signal level can be set.

Potentiometer Settings

There are five potentiometers below the LEDs, with each potentiometer having a setting range of approximately 18 turns. Turning a potentiometer clockwise increases the value. Turning the potentiometer counterclockwise lowers the value.




Figure 4-4. Potentiometer locations

Table 4-9. Potentiometer locations

Location	Function	Default
R201	Transformer adaptation (Phase angle of first half wave)	Thyro-A 1A 60° electrical phase angle Thyro-A 2A 90° electrical phase angle Thyro-A 3A 90° electrical phase angle
R202	Scale setpoint ^[1]	U-regulation: $U_{type} + 10\%$ P-regulation: $P_{type} + 10\%$
R203	Current limit ^[1]	I_{type}
R204	Scale output ^[1]	U_{type} , I_{type} , P (depending on output variable of analog output)
R205	Load monitoring ^[1]	Off (left stop)
¹ For ... HRL3 and HRLP3 only.		

Setting Aids

The LED bar graph or the analog output may be used as an aid to setting the parameter potentiometers. When a potentiometer is changed, the LED bar graph enters the setting mode. The LED bar graph changes to an orange color, and flashes rapidly.

Table 4-10. Setting aids

LED Bar Graph	Analog Output	Setting %	Corresponding Phase Angle
100%	10.0 mA/5 V	100%	100° electrical phase angle
100% dimmed ^[1]	9.0 mA/4.5 V	90%	90° electrical phase angle (default Thyro-A 2A & 3A)
80%	8.0 mA/4.0 V	80%	80° electrical phase angle
80% dimmed	7.0 mA/3.5 V	70%	70° electrical phase angle
60%	6.0 mA/3.0 V	60%	60° electrical phase angle (default Thyro-A 1A)
60% dimmed	5.0 mA/2.5 V	50%	50° electrical phase angle (default Thyro-A 1A)
40%	4.0 mA/2.0 V	40%	40° electrical phase angle
40% dimmed	3.0 mA/1.5 V	30%	30° electrical phase angle
20%	2.0 mA/1.0 V	20%	20° electrical phase angle
20% dimmed	1.0 mA/0.5 V	10%	10° electrical phase angle
¹ At 90%, the 100% LED is dimmed.			

Setting the Transformer Load

In order to minimize the rush current for transformers, it is possible to alter the angle of the first half wave on potentiometer R201 **TRAFO ADAPTION**.

Only for ... H3, before adapting the transformer load:

- Set DIP switch S1.5 to **OFF**

The settings described are relevant in operating mode TAKT.

- Set transformer load and SST on potentiometer R201 **TRAFO ADAPTION**
(default setting: 60° electrical phase angle with the Thyro-A 1A, 90° electrical phase angle with the Thyro-A 2A and Thyro-A 3A)

To control a transformer load with the Thyro-A 1A controller, typically increase the phase angle by turning R201 **TRAFO ADAPTION** to the right. With the Thyro-A 2A and Thyro-A 3A controllers, typically decrease the phase angle by turning R201 **TRAFO ADAPTION** to the left. An optimal setting is achieved when the rush current is minimal.

Setting Resistive Load

Set potentiometer R201 **TRAFO ADAPTION** to left stop.

- T0 = 100 ms

- Faster TAKT period is set
- No phase angle of first half wave is set
- Soft start time (SST) set to 0

The soft-start time (SST) is set at the same time. This also applies to operating mode VAR. The soft start time has the values shown in the following table, depending on AN1.

Table 4-11. Soft-start settings

AN1 (°Electrical Phase Angle)	SST (Period)	SST (ms/50 Hz)	Approximate Turns	LED Bar Graph	Analog Output
Thyro-A 1A					
< 30	0	0	4	40% dimmed	3.0 mA / 1.5 V
> 30.0	6	120	5	40% dimmed	3.0 mA / 1.5 V
> 33.7	7	140	6	40% dimmed	3.0 mA / 1.5 V
> 41.2	8	160	7	40%	4.12 mA / 2.06 V
> 48.7	9	180	8	60% dimmed	4.87 mA / 2.44 V
> 56.2	10	200	9	60%	5.62 mA / 2.81 V
> 61.5	11	220	10	60%	6.15 mA / 3.08 V
> 64.5	13	260	10	60%	6.45 mA / 3.23 V
> 67.4	14	300	11	80% dimmed	6.74 mA / 3.37 V
> 70.5	20	400	11	80% dimmed	7.05 mA / 3.53 V
> 73.5	30	600	12	80% dimmed	7.35 mA / 3.68 V
Thyro-A 2A, 3A					
< 30	0	0	4	40% dimmed	3.0 mA / 1.5 V
> 60	6	120	10	60%	6.0 mA / 3.0 V
> 63.7	7	140	10	60%	6.37 mA / 3.19 V
> 71.2	8	160	11	80% dimmed	7.12 mA / 3.56 V
> 78.8	9	180	12	80%	7.88 mA / 3.94 V
> 86.2	10	200	13	100% dimmed	8.62 mA / 4.31 V
> 91.5	11	220	13	100% dimmed	9.15 mA / 4.58 V
> 94.5	13	260	14	100% dimmed	9.45 mA / 4.73 V
> 97.4	14	300	14	100%	9.74 mA / 4.87 V
> 100.5	20	400	15	100%	10.0 mA / 5 V

Table 4-11. Soft-start settings (Continued)

AN1 (°Electrical Phase Angle)	SST (Period)	SST (ms/50 Hz)	Approximate Turns	LED Bar Graph	Analog Output
> 103.5	30	600 ^[1]	15	100%	10.0 mA / 5 V
¹ For an SST of 30 periods or 600 ms, the power controller remains in the SST ramp until setting time (Ts) is greater than 600 ms. The power controller then pulses without SST ramp, even if Ts is less than 600 ms. As soon as the power controller reaches the setpoint, the SST becomes smaller and the ramp is always crossed once fully.					

Important

When a bus module or Thyro-Tool Pro software is used, parameters AN1, SST, and T0 can be set independently of one another.

Set potentiometer R201 **TRAFO ADAPTION** to left stop. At < 30° electrical phase angle, the device automatically switches to a faster TAKT operation with T0 = 5 periods without SST. In this configuration, terminal X2.7 can be used as control input for switch operation.

Important

When using the synchronization options, parameter AN1 must be set to > 30° electrical phase angle via R201 **TRAFO ADAPTION** (T0 = 1000 ms).

Setting Maximum Load Value With Control End U, U² and P Control

For ... HRL3 and ... HRLP3

With potentiometer R202 **SCALE SETPOINT**, the maximum voltage (for U, U² control) or the maximum power (for P control) is set on the load, depending on the control mode. If no P control is set, the potentiometer works as voltage limitation. The end value of the control characteristic is adapted accordingly (see following table).

Table 4-12. Maximum load value

Setting	U _{load max} Potentiometer SCALE SETPOINT	P _{load max} ^[1] Potentiometer SCALE SETPOINT
Thyro-A 1A, 2A		
Potentiometer turns (from left stop)	$9 * U_{load\ max} / U_{type}$	$7.8 * P_{load\ max} / P_{type}$
Setting aid, analog output in mA (Switch S1.10 = OFF)	$10\ mA * U_{load\ max} / U_{type}$	$8.66\ mA * P_{load\ max} / P_{type}$

Table 4-12. Maximum load value (Continued)

Setting	$U_{load\ max}$ Potentiometer SCALE SETPOINT	$P_{load\ max}$ ^[1] Potentiometer SCALE SETPOINT
Setting aid, analog output gang in volts (Switch S1.10 = ON)	$5\ V * U_{load\ max} / U_{type}$	$4.33\ V * P_{load\ max} / P_{type}$
Setting aid LED bar graph	$100\% * U_{load\ max} / U_{type}$	$88.6\ \% * P_{load\ max} / P_{type}$
Thyro-A 3A		
Potentiometer turns (from left stop)	$9 * U_{load\ max} / U_{type}$	$5.2 * P_{load\ max} / P_{type}$
Setting aid, analog output in mA (Switch S1.10 = OFF)	$10\ mA * U_{load\ max} / U_{type}$	$5.77\ mA * P_{load\ max} / P_{type}$
Setting aid, analog output gang in volts (Switch S1.10 = ON)	$5\ V * U_{load\ max} / U_{type}$	$2.89\ V * P_{load\ max} / P_{type}$
Setting aid LED bar graph	$100\% * U_{load\ max} / U_{type}$	$57.7\ \% * P_{load\ max} / P_{type}$
[/] HRLP3 only		

Set maximum load value (of U or P) at control end on potentiometer R202 **SCALE SETPOINT**.

Setting Maximum Load Value With Control End U, U²

For ... H3

When DIP switch S1.5 is set to **ON**, the maximum load voltage (with U/U² control) can be defined on potentiometer R201 **TRAFO ADAPTION**. The control characteristic curve is adapted in accordance with the following equations:

- Potentiometer turns (from left stop) = $9 * U_{load\ max} / U_{type}$
- Analog output in mA (Switch S1.10 = **OFF**) = $10\ mA * U_{load\ max} / U_{type}$
- Analog output in volts (Switch S1.10 = **ON**) = $5\ V * U_{load\ max} / U_{type}$
- LED bar graph = $100\% * U_{load\ max} / U_{type}$

Setting Maximum Load Current

For ... HRL3 and ... HRLP3

The maximum load current is limited with potentiometer R203 **CURRENT LIMIT**, regardless of the control mode. If there is no I control, the potentiometer works as current limiter. At reduced ambient temperatures, the power controller can only be operated with up to 110% of its nominal current (effective value).

Table 4-13. Maximum load current

Setting	$I_{load\ max}$ Potentiometer R203 CURRENT LIMIT
Potentiometer turns (from left stop)	$9 * I_{load\ max} / I_{type}$
Setting aid, analog output in mA (Switch S1.10 = OFF)	$10\ mA * I_{load\ max} / I_{type}$
Setting aid, analog output in volts (Switch S1.10 = ON)	$5\ V * I_{load\ max} / I_{type}$
Setting aid LED bar graph	$100\% * I_{load\ max} / I_{type}$

Analog output: X2.9 (+); X2.5 (ground). When the current limit is reached, the red **LIMIT** LED flashes. See [Table 4-2](#) on page 4-3.

- Set maximum load current at potentiometer R203 **CURRENT LIMIT**.

Setting Example for Maximum Load Value at Control End / Maximum Load Current

Example for maximum load value / maximum load current Thyro-A 3A 400-30 HRLP3 (Utype= 400 V, Itype= 30 A, Ptype=20.7 kW):

- Power control with limit to 15 kW
- Current limit to 25 A

Limit power to 15 kW:

- Setting aid in turns: $7.8 * (15\ kW / 20.7\ kW) = R202$ at 5.7 turns (from left stop)
- Setting aid in mA: $8.66\ mA * (15\ kW / 20.7\ kW) = 6.25\ mA$
- Setting aid in V: $4.33\ V * (15\ kW / 20.7\ kW) = 3.13\ V$
- Setting aid LED bar graph: $86.6\% * (15\ kW / 20.7\ kW) = 62\% \approx 60\%$ LED

Limit current to 25 A:

- Setting aid in turns: $9 * (25\ A / 30\ A) = R203$ at 7.5 turns (from left stop)
- Setting aid in mA: $10\ mA * (25\ A / 30\ A) = 8.33\ mA$
- Setting aid in V: $5\ V * (25\ A / 30\ A) = 4.16\ V$
- Setting aid LED bar graph: $100\% * (25\ A / 30\ A) = 83\% \approx 80\%$ LED lit

Adapting Analog Output (Scale)

For ... HRL3 and ... HRLP3

The scale of the analog output is adapted with potentiometer R204 **SCALE OUTPUT**, if, for example, the scale of the display does not correspond to the nominal data.

Default = 0 mA to 20 mA, corresponds to type value (current/voltage/power).

Table 4-14. Analog output scaling for voltage and current

Setting	U-, I Display Potentiometer R204 SCALE OUTPUT
Potentiometer turns (from left stop)	3.6 turns * (type value power / controller / scale end value)
Analog output setting aid mA (Switch S1.10 = OFF)	4 mA * (type value power controller / scale end value)
Analog output setting aid V (Switch S1.10 = ON)	2 V * (type value power controller / scale end value)
LED bar graph	40% * (type value power controller / scale end value)

Table 4-15. Analog output scaling for power

Setting	P Display ¹ - Potentiometer R204 SCALE OUTPUT		
	Thyro-A 1A	Thyro-A 2A	Thyro-A 3A
Potentiometer turns (from left stop)	3.6 turns * (type value power / controller / scale end value)	4.16 turns * (Ptype power controller / scale end value)	6.24 turns * (Ptype power controller / scale end value)
Analog output setting aid mA (Switch S1.10 = OFF)	4 mA * (type value power controller / scale end value)	4.62 mA * (Ptype power controller / scale end value)	6.93 mA * (Ptype power controller / scale end value)
Analog output setting aid V (Switch S1.10 = ON)	2 V * (type value power controller / scale end value)	2.13 V * (Ptype power controller / scale end value)	3.46 V * (Ptype power controller / scale end value)
LED bar graph	40% * (type value power controller / scale end value)	46.2% * (type value power controller / scale end value)	69.3% * (type value power controller / scale end value)
¹ Only with ... HRLP3			

For example, to scale the analog output of a Thyro-A 3A 400-30 HRLP3 (Utype = 400 V, Itype = 30 A, Ptype = 20.7 kW), for a measuring instrument range of 4 mA to 20 mA, with full scale at 20 kW:

- Setting aid in turns, R204: $6.24 * (20.7 \text{ kW} / 20 \text{ kW}) = 6.5$ turns (from left stop)
- Setting aid in mA: $6.93 \text{ mA} * (20.7 \text{ kW} / 20 \text{ kW}) = 7.17 \text{ mA}$
- Setting aid in V: $3.46 \text{ V} * (20.7 \text{ kW} / 20 \text{ kW}) = 3.58 \text{ V}$
- Setting aid LED bar graph: $69.3\% * (20.7 \text{ kW} / 20 \text{ kW}) = 72\% \approx 80\%$ LED dimmed

Setting Load Monitoring (Undercurrent Monitoring)

For ... HRL3 and ... HRLP3

This function enables a freely selectable absolute current limit to be monitored. The value can be set using the R205 **LOAD FAULT** potentiometer or the Thyro-Tool Pro software.

During the configuration process via potentiometer, the monitoring value will be indicated at the analog output and by the LED bar graph. This monitoring of absolute values is suitable for one or several load resistors set up in parallel. The effective value of the current measured is continually compared with a configurable absolute current limit for undercurrent. If the current drops below this limit, a message is sent. In the case of resistors set up in parallel, a partial load break can be detected by setting the appropriate undercurrent limit.

- Set load monitoring on potentiometer R205 **LOAD FAULT**.

The default setting of this monitoring is OFF (= left stop of potentiometer R205 **LOAD FAULT**). A measuring instrument connected to the analog output and the LED bar graph can be used as a setting aid. If the actual value has fallen below the set value, a message is sent (LED, by bus, and fault signaling relay K1).

Important

Settings less than 10% and over 90% are not practical. If the load currents are considerably less than the nominal currents of the power controller, consider using a smaller power controller.

- In operating mode VAR, monitoring is blocked for large control angles (for load with neutral conductor $\alpha > 140^\circ$ electrical phase angle and for load without neutral conductor $\alpha > 117^\circ$ electrical phase angle).
- The signaling delays can be up to 15 seconds in operating mode VAR and up to 30 seconds in operating mode TAKT.
- Convert deviating values as a percentage. The set monitoring value should always be an average of the value for load nominal current and the value after failure.

See [“Monitoring Parallel Loads”](#) on page 5-34 for more information.

Analog and Digital I/O

There is one standard I/O connector on the front of the unit:

- μ USB connector **X5**, for configuration using a PC

Important

Do not start a USB connection while the controller is controlling a critical process. A short output interruption might occur.





Figure 4-5. Front I/O connector

The type HRL3 and HRLP3 units have six connectors on the bottom of the unit:

- AC phase connection **X1**
- AC phase connection **X10** (present only on some 3-phase units)
- Auxiliary power input **X11**
- Analog I/O connector **X2**
- Bus module connector **X22**
- Fault relay K1 connector **X3**



*For units < 45 A, L1 is labeled 1, T1 is labeled 2

Figure 4-6. Bottom connectors

Important

All digital and analog control cables must be shielded. Connect the cable shields to the shield terminal on the unit.

Table 4-16. AC phase connection (X1)

Pin	Function
X1.1	For 1-phase and 2-phase units, add L2 or N connection according to the connection diagram (see “ Connection Diagrams ” on page 5-20). Do not alter the factory wiring.
X1.2	For 1-phase and 2-phase units, add L2 or N connection according to the connection diagram (see “ Connection Diagrams ” on page 5-20). Do not alter the factory wiring.

Table 4-17. AC phase connection (X10) (present only on some 3-phase units)

Pin	Function
X10.1	Factory wired, do not alter
X10.2	Factory wired, do not alter

Table 4-18. AC/DC auxiliary power input (X11)

Pin	Function
X11.1	24 V AC or +24 V DC (optional connection)
X11.2	24 V AC or –24 V DC (optional connection)

Table 4-19. 11-pin analog I/O connector (X2)

Pin	Function
X2.1	Control ground
X2.2	Pulse lock
X2.3	Control ground
X2.4	Analog setpoint, 10 V maximum or 20 mA maximum

Table 4-19. 11-pin analog I/O connector (X2) (Continued)

Pin	Function
X2.5	Control ground
X2.6	Sync out
X2.7	Sync in
X2.8	+5 V
X2.9	Analog output (setpoint potentiometer power 0 V to 10 V, or 0 (4) mA to 20 mA)
X2.10	Control cable shield
X2.11	Feedback input 0 (4) mA to 20 mA

Table 4-20. 7-pin bus module connector (X22)

Pin	Function
X22.1	Bus module detection/setpoint selection
X22.2	TxD
X22.3	RxD
X22.4	Control ground
X22.5	Satellite connection
X22.6	Satellite connection
X22.7	Control ground

Table 4-21. Relay K1 connectors (X3)

Pin	Function
X3.1	Common
X3.2	Normally open
X3.3	Normally closed

Related Links

- [“Connecting I/O and Auxiliary Connectors” on page 5-17](#)

Software User Interface

The optional Thyro-Tool Pro software is available for commissioning and visualization. This software can be used to:

- Update firmware
- Set and display parameters

- Display current operating conditions and events
- Create a time-stamped data record
- Create data charts

Important

Do not start a USB connection while the controller is controlling a critical process. A short output interruption might occur.

Installation, Setup, and Operation

Preparing to Install the Unit

Spacing Requirements

Install the unit in a vertical orientation to ensure that thyristors attached to heat sinks are adequately ventilated. If you intend to mount this unit in a cabinet, ensure that the cabinet itself is adequately ventilated, and that the following requirements are met.

- The minimum distance between the bottom of the unit and the bottom of the cabinet or any other object is 100 mm (4").
- The minimum distance between the top of the unit and the top of the cabinet or any other object is 150 mm (6").
- The minimum distance between the top of the unit and the bottom of another unit is 150 mm (6").
- Units may be installed side-by-side with no intervening distance.
- Ensure that the unit is not exposed to sources of heat.

Dimensional Drawings

The following figures show Thyro-A unit dimensions, front, and side views.




Figure 5-1. Thyro-A 1A 8 H, 16 H, 30 H




Figure 5-2. *Thyro-A 1A 45 H, 60 H*




Figure 5-3. *Thyro-A 1A 100 H*




Figure 5-4. Thyro-A 1A 130 H, 170 H




Figure 5-5. Thyro-A 1A 280 HF




Figure 5-6. Thyro-A 1A 350 HF




Figure 5-7. Thyro-A 1A 495 HF, 650 HF




Figure 5-8. Thyro-A 1A 495 HF, 650 HF C32




Figure 5-9. Thyro-A 1A 1000 HF, 1400 HF, 1500 HF




Figure 5-10. Thyro-A 2A 8 H, 16 H, 30 H




Figure 5-11. Thyro-A 2A 45 H, 60 H




Figure 5-12. Thyro-A 2A 100 H




Figure 5-13. Thyro-A 2A 130 H, 170 H




Figure 5-14. Thyro-A 2A 280 HF




Figure 5-15. Thyro-A 2A 350 HF




Figure 5-16. *Thyro-A 2A 495 HF, 650 HF*




Figure 5-17. *Thyro-A 2A 1000 HF, 1400 HF, 1500 HF*




Figure 5-18. Thyro-A 3A 8 H, 16 H, 30 H




Figure 5-19. Thyro-A 3A 45 H, 60 H




Figure 5-20. *Thyro-A 3A 100 H*




Figure 5-21. *Thyro-A 3A 130 H, 170 H*




Figure 5-22. Thyro-A 3A 280 HF




Figure 5-23. Thyro-A 3A 350 HF




Figure 5-24. Thyro-A 3A 495 HF, 650 HF




Figure 5-25. Thyro-A 3A 1000 HF, 1400 HF, 1500 HF

Installation Requirements

Install this unit according to the following requirements.



DANGER:

RISK OF DEATH OR BODILY INJURY. Follow your local jurisdiction requirements for lockout/tagout prior to connecting or disconnecting all input power sources and output connections.



DANGER:

RISQUE DE MORT OU DE BLESSURES. Respectez les exigences de votre juridiction locale en matière de verrouillage/étiquetage avant de connecter ou de déconnecter toutes les sources d'alimentation d'entrée et les connexions de sortie.

**DANGER:**

Personnel must receive proper training before installing or troubleshooting high-energy electrical equipment. Potentially lethal voltages could cause death, serious personal injury, or damage to the equipment. Ensure that all appropriate safety precautions are taken.

**DANGER:**

Le personnel devra être correctement formé avant de pouvoir installer ou dépanner des équipements électriques à haute énergie. Des tensions potentiellement létales peuvent entraîner le décès, des blessures ou des dommages à l'équipement. Assurez-vous de prendre toutes les précautions de sécurité appropriées.

Unpacking the Unit

Important

The labels on the packaging provide important safety and handling information. Follow company procedures when unpacking the unit.

1. Unpack and inspect the unit carefully, looking for obvious physical damage.
2. If no damage is apparent, proceed with the unit installation and setup.
3. If signs of shipping damage are found, contact AE Technical Support and the carrier immediately.

Save the shipping container for submitting necessary claims to the carrier.

Lifting the Unit

Use appropriate lifting techniques and tools based on the size and weight of the unit.

**CAUTION:**

The module is heavy. Use two people to lift the module.

**ATTENTION:**

Le module est lourd. Il doit être soulevé par deux personnes.

1. Review your company procedures before lifting the Thyro-A power controller.
2. Lift the Thyro-A power controller by holding on to the front of the unit while also supporting the rear of the unit.

Installing the Unit

Mounting the Unit

1. Install the unit on or in the mounting surface, rack, or cabinet.
2. Fasten the unit to the mounting surface, rack, or cabinet. Use suitable fasteners.

See “[Dimensional Drawings](#)” on page 5-1 for mounting hole details.

Grounding



WARNING:

Do not attempt to turn on power until the chassis of the unit is tied to a local earth ground through a copper grounding wire that is sized in accordance with applicable requirements.



AVERTISSEMENT:

N'essayez pas d'allumer l'alimentation jusqu'à ce que le châssis de l'unité soit attaché à un sol de terre local au moyen d'un fil de mise à la terre en cuivre dimensionné conformément aux exigences applicables.

- Make a suitable chassis ground connection to the location specified on the dimensional drawing. See “[Dimensional Drawings](#)” on page 5-1.

Connecting I/O and Auxiliary Connectors



DANGER:

RISK OF DEATH OR BODILY INJURY. Follow your local jurisdiction requirements for lockout/tagout prior to connecting or disconnecting all input power sources and output connections.



DANGER:

RISQUE DE MORT OU DE BLESSURES. Respectez les exigences de votre juridiction locale en matière de verrouillage/étiquetage avant de connecter ou de déconnecter toutes les sources d'alimentation d'entrée et les connexions de sortie.

Important

All digital and analog control cables must be shielded. Connect the cable shields to the shield terminal on the unit.

The following signals are always required for operation of the device: *SETPPOINT*, *PULSE LOCK*.

Complete the following steps to connect each control cable required for your installation. A plug-in, screw-terminal block is provided for each control connector.

1. Verify that the control cable conductors are sized between 0.14 mm² and 1.5 mm² (30 AWG and 14 AWG).
2. Prepare the end of the control cable:
 - a. Strip 50 mm (2") of the cable jacket.
 - b. Prepare the cable shield for connection to the shield terminal.
 - c. Strip 7 mm (0.28") of insulation from each conductor.
3. Connect each conductor to the plug-in, screw-terminal block.
4. Connect the cable shield to the shield terminal, X2.10.
5. Plug the block into the power controller.

Related Links

- [“Analog and Digital I/O” on page 4-16](#)

Connecting Load and Auxiliary Power



DANGER:

RISK OF DEATH OR BODILY INJURY. Follow your local jurisdiction requirements for lockout/tagout prior to connecting or disconnecting all input power sources and output connections.



DANGER:

RISQUE DE MORT OU DE BLESSURES. Respectez les exigences de votre juridiction locale en matière de verrouillage/étiquetage avant de connecter ou de déconnecter toutes les sources d'alimentation d'entrée et les connexions de sortie.



WARNING:

This device must be installed so that the output power connection is inaccessible to the user.



AVERTISSEMENT:

Le dispositif doit être installé de façon à ce que l'utilisateur ne puisse accéder à la connexion de puissance de sortie.

This task applies to all units. Three-phase units will have three mains input terminals and three load terminals. Two-phase and 1-phase units will have two sets or one set of mains terminals and load terminals, and will require a reference phase connection

to connector **X1**, as shown in the connection diagram (see “[Connection Diagrams](#)” on page 5-20).

To Connect Load and Auxiliary Power

1. Press on the retaining clip on the front of the unit(s), and slide the plastic cover(s) forward to remove.
2. Verify that the Protective Earth ground conductor is connected.
3. Connect each phase of the mains supply to the mains terminal (**L1**, **L2**, **L3**).

Important

A clockwise rotating field is required. The mains terminals are labeled **1** on units with less than a 45 A current rating.

- a. Use the screw size specified in [Table 5-1](#).
 - b. Tighten to the torque specified in [Table 5-2](#).
4. Connect each phase of the load to the load terminals (**T1**, **T2**, **T3**).

Important

The load terminals are labeled **2** on units with less than a 45 A current rating.

- a. Use the screw size specified in [Table 5-1](#).
 - b. Tighten to the torque specified in [Table 5-2](#).
5. For 1-phase and 2-phase units only, connect terminal **X1.1** on the bottom of the unit:
 - To the neutral conductor (1-phase units)
 - To the mains side of L2 through an external 2 A fuse (1-phase or 2-phase units)

An external 2 A fuse might be required. Use the included plug-in, screw-terminal block to make this connection. Do not alter any existing factory wiring connected to this terminal block.

6. To use the unit beyond the normal voltage range, connect a current-limited external 24 V power source to the power input connector **X11** on the bottom of the unit.

External 24 V auxiliary power allows bus communication operation during mains faults.

7. For HF units, connect the 230 V AC (or 115 V AC special option) fan power supply to connector **X7**.

Use the included plug-in, screw-terminal block to make this connection. Follow the torque recommendation for M2 terminal screws.

8. For 1-phase units of 495 A or 650 A rating C32 variance, connect a 24 V DC fan power supply to connector **X7**.

Use the included plug-in, screw-terminal block to make this connection. Follow the torque recommendation for M2 terminal screws.

9. Reinstall the plastic cover(s) removed for step 1.

Table 5-1. Terminal screw size

Model	Connector Screw	Protective Earth Screw
8 A, 16 A, 30 A	Lug, M4	Lug, M4
45 A, 60 A, 100 A	M6	M6
130 A, 170 A	M8	M10
280 A, 350 A, 495 A, 650 A	M10	M10
1000 A, 1400 A, 1500 A	M12	M12

Table 5-2. Terminal screw torque

Screw	Torque		
	Minimum NM (Pound-Inches)	Rated NM (Pound-Inches)	Maximum NM (Pound-Inches)
M2	0.2 (1.8)	0.25 (2.2)	0.3 (2.7)
M4	1.0 (8.9)	1.3 (11.5)	1.7 (15.0)
M6	3.0 (26.6)	4.4 (38.9)	5.9 (52.2)
M8	11.5 (101.8)	17.0 (150.5)	22.5 (199.1)
M10	22.0 (194.7)	33.0 (292.1)	44.0 (389.4)
M12	38.0 (336.3)	56.0 (495.6)	75.0 (663.8)

Connection Diagrams



DANGER:

RISK OF DEATH OR BODILY INJURY. Follow your local jurisdiction requirements for lockout/tagout prior to connecting or disconnecting all input power sources and output connections.



DANGER:

RISQUE DE MORT OU DE BLESSURES. Respectez les exigences de votre juridiction locale en matière de verrouillage/étiquetage avant de connecter ou de déconnecter toutes les sources d'alimentation d'entrée et les connexions de sortie.



WARNING:

More than one live circuit. See diagram.



AVERTISSEMENT:

Plus d'un circuit est sous tension. Voir schéma.




Figure 5-26. 1A power controller connections




Figure 5-27. 2A power controller connections




Figure 5-28. 3A power controller connections

Installation as a Voltage Sequence Controller (VSC)

**DANGER:**

RISK OF DEATH OR BODILY INJURY. Follow your local jurisdiction requirements for lockout/tagout prior to connecting or disconnecting all input power sources and output connections.

**DANGER:**

RISQUE DE MORT OU DE BLESSURES. Respectez les exigences de votre juridiction locale en matière de verrouillage/étiquetage avant de connecter ou de déconnecter toutes les sources d'alimentation d'entrée et les connexions de sortie.

**DANGER:**

Personnel must receive proper training before installing or troubleshooting high-energy electrical equipment. Potentially lethal voltages could cause death, serious personal injury, or damage to the equipment. Ensure that all appropriate safety precautions are taken.

**DANGER:**

Le personnel devra être correctement formé avant de pouvoir installer ou dépanner des équipements électriques à haute énergie. Des tensions potentiellement létales peuvent entraîner le décès, des blessures ou des dommages à l'équipement. Assurez-vous de prendre toutes les précautions de sécurité appropriées.

**WARNING:**

These servicing instructions are for use by qualified personnel only. To reduce the risk of electric shock, do not perform any servicing other than that specified in the operating instructions.

**AVERTISSEMENT:**

Ces instructions d'entretien sont destinées uniquement à un personnel qualifié. Pour réduire le risque d'électrocution, ne pas effectuer un entretien autre que celui spécifié dans les instructions de fonctionnement.

For applications with single or multiple transformer-coupled heating zones, voltage sequence control (VSC) technology offers fast response, high control dynamics, and high control resolution per cycle of phase-angle mode, while reducing reactive power, decreasing harmonics, and significantly improving power factor. VSC is useful for grid load optimized, highly dynamic heating processes.

The Thyro-A power controllers with options C03, C05, and C23 are factory configured for primary, two-stage VSC.

Primary VSC is particularly suitable for large load currents ($I_{Load} > I_{Controller}$) with smaller voltages. One transformer is used for each load. The following illustrations show the two stage VSC connections.



CAUTION:

In the primary VSC configuration, the mains voltage is stepped up on the inactive power controller outputs, marked * in the following figure. The transformer must be designed so that this voltage does not exceed the type voltage (500 V or 690 V) of the unit, or the unit will be damaged.



ATTENTION:

Dans la configuration principale de VSC, la tension de l'alimentation secteur est élevée sur les sorties du contrôleur de puissance inactive, indiqué par * dans l'illustration suivante. Le transformateur doit être conçu de façon à ce que la tension n'excède pas la tension type de l'appareil (500 V ou 690 V); autrement l'appareil pourrait être endommagé.




Figure 5-29. Primary VSC

To Install as a VSC Controller

1. Install the unit as described in “[Installing the Unit](#)” on page 5-17
2. When connecting the load, use the following Thyro-A VSC connection diagram: [Figure 5-30](#) on page 5-27.




Figure 5-30. 2-phase as VSC 2

First Time Operation

On delivery, the device is parameterized to the respective power section. The TAKT operating mode is set on 1-phase and 2-phase units, and the VAR operating mode is set on 3-phase units. You should review these standard parameters, and, if necessary, adjust them for your application.

To Operate the Thyro-A Unit for the First Time

1. Install the unit according to the installation procedures in this user manual.

The minimum connections are power, load, *SETPOINT*, and *PULSE LOCK* jumper.

2. Turn on the system circuit breakers and apply AC input to the unit.
3. Verify that the amber **ON / READY** LED is lit.

When the unit receives AC input, it performs self-diagnostics. If the unit detects an error, the unit sets the respective fault bits and lights the appropriate LED (see [Table 4-2](#) on page 4-3). You will not be able to apply power to the load until you clear the fault.

4. Verify that an increase in setpoint applies power to the load.

If the Thyro-A unit is delivering power, the unit is functioning properly.

Important

AE recommends that you update the firmware to the latest revision using the Thyro-Tool Pro software.

Related Links

- [“Operating Modes” on page 5-29](#)
- [“Software User Interface” on page 4-18](#)

Normal Operation

Each time you turn the unit on, the unit runs a self-diagnostics procedure to ensure that it is performing correctly. Follow the procedures in this user manual for first time operation the first time you operate your unit. Consult the troubleshooting section if you have issues or problems operating your unit after you have followed the first time operation guidelines.

You can monitor your unit with a system (user-supplied) controller or a Windows®-based personal computer running Thyro-Tool Pro software. To order this software, contact your AE sales representative.

Operating Modes

Full-Wave Switch (TAKT)

In full-switch mode, whole multiples of the mains periods are always switched and harmonics are minimized.

The mains are switched on/off depending on the prescribed time period.




Figure 5-31. TAKT waveform

Phase-Angle Firing (VAR)

Depending on the prescribed setpoint, the sine oscillation of the mains voltage is gated using a larger or smaller control angle α . This operating mode is characterized by high control dynamics.




Figure 5-32. VAR waveform

Half-Wave Switch QTM (Quick TAKT Mode)

QTM is an operating mode which works on the half wave switch principle, and is only available on single-phase units. QTM is suitable for resistive loads and is particularly suited for IR heaters as an alternative to phase-angle control. Whole mains half-wave periods are switched so that harmonics are minimized.




Figure 5-33. QTM waveform

Switch Mode (SWITCH)

In switch mode, the mains voltage is switched on when the setpoint exceeds 50%, or the *Sync In* (X2.7) signal is on. This means that on-off control can be realized. Whole multiples of the mains periods are always switched and harmonics are minimized. The switch mode is suitable for resistive load and transformer load.

Setpoint Control

You can adapt the setpoint signal to either process controllers or to the automation system by altering the starting and finishing points of the control characteristic curve. All common control signal types can be used. LEDs indicate when the power controller reaches a limit value (U_Max, I_Max, P_Max)..




Figure 5-34. Setpoint inputs

The power controller has two setpoint inputs that are electrically isolated from the mains and of which only one is ever active.

- Setpoint 1: Analog signal X2.4 (+); X2.3 (ground)
- Setpoint 2: Via system interface (bus module, Thyro-Tool Pro software)

The setpoint input to be used is defined by configuring terminal X22.1. Setpoint 1 is selected when X22.1 is open. Setpoint 2 is selected when X22.1 is connected to X22.4 (ground).

Switch Mode Setpoint

When operating in switch mode, a setpoint above 50% causes the load to be switched on; a setpoint below 50% causes the load to be switched off. You can also use a digital signal (5 V to 24 V) to terminal X2.7 (*Sync In*) to switch the load on and off.

Control Types

The Thyro-A power controller has six control types effective as underlying controls. Mains voltage variations and load changes are directly and quickly adjusted by bypassing the slow temperature control system.

Before commissioning the power controller and selecting a control type, you should be familiar with the application and with the operating characteristics of the load.

Controlled Value

The controlled value effect on the load is proportional to the total setpoint, depending on the control type, as shown in the following table.

Table 5-3. Control modes

Control Mode	Control Value
Type H3	
U control	Output voltage, U_{RMS}
U^2 control	Output voltage, U^2_{RMS}
No regulation	Output proportional to the setpoint
Type HRL3	
U control	Output voltage, U_{RMS}
U^2 control	Output voltage, U^2_{RMS}
I control	Output current, I_{RMS}
I^2 control	Output current, I^2_{RMS}
No regulation	Output proportional to the setpoint
Type HRLP3	
U control	Output voltage, U_{RMS}
U^2 control	Output voltage, U^2_{RMS}
I control	Output current, I_{RMS}
I^2 control	Output current, I^2_{RMS}
P control	Output (active) power, P
No regulation	Output proportional to the setpoint

Control Characteristic Curves

The control variable influencing the load is proportional to the effective setpoint in the case of control modes U, I, and P. In control modes U^2 and I^2 , the control variable influencing the load is a square of the effective setpoint.

The control characteristic curves are shown in the following three figures.




Figure 5-35. U control




Figure 5-36. I control




Figure 5-37. P control

Controller Response

If the load resistance changes (for example, due to temperature effect, aging, or load fault), the power controller responds as shown in the following table.

Table 5-4. Response to load changes

Control Type	Limit	Load Resistance Decreases			Load Resistance Increases			Effective Limitations ^[1]	
		P	U _{LOAD}	I _{LOAD}	P	U _{LOAD}	I _{LOAD}		
U	U _{RMSmax}	Larger	=	Larger	Smaller	=	Smaller	I _{RMSmax}	P _{max}
U ²	U _{RMSmax}	Larger	=	Larger	Smaller	=	Smaller	I _{RMSmax}	P _{max}
I	I _{RMSmax}	Smaller	Smaller	=	Larger	Larger	=	U _{RMSmax}	P _{max}
I ²	I _{RMSmax}	Smaller	Smaller	=	Larger	Larger	=	U _{RMSmax}	P _{max}
P	P _{max}	=	Smaller	Larger	=	Larger	Smaller	U _{RMSmax}	I _{RMSmax}
Without control		Larger	=	Larger	Smaller	=	Smaller	U _{RMSmax} P _{max}	I _{RMSmax}
General modulation limit								T _s =T _{smax} α=α _{max}	
¹ If one of the limits is exceeded, then the limit relay K2 and the Limit LED react (default values of parameter settings).									

Monitoring

Faults occurring in the power controller or in the load circuit are signaled. Signaling is performed via the LED indicators, and via the fault relay K1. See LED table [Table 4-2](#) on page 4-3.

Mains Voltage Monitoring

The power controller is equipped with mains voltage monitoring. You can set the limits for U mains minimum and U mains maximum. A status message will be generated when either limit is reached.

Important

The following limit values apply for voltage monitoring:

- Undervoltage monitoring: -57% of type voltage
- Overvoltage monitoring: +10% of type voltage

This results in absolute limit values for the monitoring of the mains voltage.

Table 5-5. Limit values for mains voltage monitoring

Type	Undervoltage Limit	Overvoltage Limit
230 V	99 V	253 V
400 V	172 V	440 V
500 V	215 V	550 V

For ... HRL3 and ... HRLP3 only: In the event of more than 15% below the type voltage, the devices can only be operated up to the undervoltage limit if the electronics are supplied from an external 24 V source.

For ... H3, ... HRL3 and ... HRLP3: In default state, *PULSE LOCK* is switched internally when the undervoltage limit is exceeded, and fault relay K1 de-energizes. Both can be set with the Thyro-Tool Pro software.

Device Temperature and Fan Monitoring

The Thyro-A unit has temperature monitoring. If the temperature exceeds 90°C (194°F), the unit sends a message via LED, via the bus module, or via fault relay K1. The *PULSE LOCK* is actuated but can be deactivated. Note that if you deactivate the *PULSE LOCK*, you run the risk of overheating and/or damaging the unit.

For units with fans, the device temperature monitoring indirectly monitors the fan.

In case of a temperature overrange, the unit will switch off and the **FAULT** LED will blink with blink code 3.

Important

When using the unit under UL conditions, switch on this feature.

Monitoring Parallel Loads

For ... HRL3 and ... HRLP3

This function enables a freely selectable absolute current limit to be monitored. The value can be set using the R205 **LOAD FAULT** potentiometer or the Thyro-Tool Pro software.

During the configuration process via potentiometer, the monitoring value will be indicated at the analog output and by the LED bar graph. This monitoring of absolute values is suitable for one or several load resistors set up in parallel. The effective value of the current measured is continually compared with a configurable absolute current limit for undercurrent. If the current drops below this limit, a message is sent. In the case of resistors set up in parallel, a partial load break can be detected by setting the appropriate undercurrent limit.

- Set load monitoring on potentiometer R205 **LOAD FAULT**.

The default setting of this monitoring is OFF (= left stop of potentiometer R205 **LOAD FAULT**). A measuring instrument connected to the analog output and the

LED bar graph can be used as a setting aid. If the actual value has fallen below the set value, a message is sent (LED, by bus, and fault signaling relay K1).

Important

Settings less than 10% and over 90% are not practical. If the load currents are considerably less than the nominal currents of the power controller, consider using a smaller power controller.

- In operating mode VAR, monitoring is blocked for large control angles (for load with neutral conductor $\alpha > 140^\circ$ electrical phase angle and for load without neutral conductor $\alpha > 117^\circ$ electrical phase angle).
- The signaling delays can be up to 15 seconds in operating mode VAR and up to 30 seconds in operating mode TAKT.
- Convert deviating values as a percentage. The set monitoring value should always be an average of the value for load nominal current and the value after failure.

See “[Setting Load Monitoring \(Undercurrent Monitoring\)](#)” on page 4-15 for more information.

Thyro-A 1A and Thyro-A 2A With Separate Star Point




Figure 5-38. Load with separate star point and without neutral conductor

For Thyro-A 1A and Thyro-A 2A (load with separate star point without N), a setting for load monitoring can be made according to the following table:

Table 5-6. Load with separate star point and without neutral conductor

Number of Parallel Load Resistors	$I_{LOAD\ NOM} / I_{TYPE\ CONTROL-ER}$	Current in Case of Fault	Setting Aid LED Bar Graph	Setting Aid at Actual Value Output X2.9 (0 V to 5 V)	Setting Aid at Actual Value Output X2.9 (0 mA to 20 mA)	Number of Potentiometer Turns From Left Stop
1	100%	0%	50.0%	2.5 V	5 mA	8.5
	80%		40.0%	2 V	4 mA	7
	60%		30.0%	1.5 V	3 mA	6
	40%		20.0%	1 V	2 mA	4.5
	20%		10.0%	0.5 V	1 mA	2.5

Table 5-6. Load with separate star point and without neutral conductor (Continued)

Number of Parallel Load Resistors	$I_{LOAD\ NOM} / I_{TYPE\ CONTROLLER}$	Current in Case of Fault	Setting Aid LED Bar Graph	Setting Aid at Actual Value Output X2.9 (0 V to 5 V)	Setting Aid at Actual Value Output X2.9 (0 mA to 20 mA)	Number of Potentiometer Turns From Left Stop
2	100%	50%	75.0%	3.75 V	7.5 mA	12
	80%		60.0%	3 V	6 mA	9.5
	60%		45.0%	2.25 V	4.5 mA	7.5
	40%		30.0%	1.5 V	3 mA	6
	20%		15.0%	0.75 V	1.5 mA	3.5
3	100%	66%	83.3%	4.15 V	8.35 mA	13
	80%		66.7%	3.35 V	6.65 mA	10.5
	60%		50.0%	2.5 V	5 mA	8.5
	40%		33.3%	1.65 V	3.35 mA	6
4	100%	75%	87.5%	4.4 V	8.75 mA	13.5
	80%		70.0%	3.5 V	7 mA	11.5
	60%		52.5%	2.65 V	5.25 mA	9
	40%		35.0%	1.75 V	3.5 mA	6
5	100%	80%	90.0%	4.5 V	9 mA	14
	80%		72.0%	3.6 V	7.2 mA	11.5
	60%		54.0%	2.7 V	5.4 mA	9
	40%		36.0%	1.8 V	3.6 mA	6.5

Thyro-A 2A With Star and Delta Loads


**Figure 5-39.** Load with common star point and without neutral conductor

Table 5-7. Load with common star point and without neutral conductor

Number of Parallel Load Resistors	$I_{LOAD\ NOM} / I_{TYPE\ CONTROLLER}$	Current in Case of Fault	Setting Aid LED Bar Graph	Setting Aid at Actual Value Output X2.9 (0 V to 5 V)	Setting Aid at Actual Value Output X2.9 (0 mA to 20 mA)	Number of Potentiometer Turns From Left Stop
1	100%	0%	50.0%	2.5 V	5 mA	8.5
	80%		40.0%	2 V	4 mA	7
	60%		30.0%	1.5 V	3 mA	6
	40%		20.0%	1 V	2 mA	4.5
	20%		10.0%	0.5 V	1 mA	2.5
2	100%	60%	80.0%	4 V	8 mA	12
	80%		63.0%	3.15 V	6.3 mA	10
	60%		48.0%	2.4 V	4.8 mA	8
	40%		32.0%	1.6 V	3.2 mA	5.5
	20%		16.0%	0.8 V	1.6 mA	3.5
3	100%	75%	87.0%	4.35 V	8.7 mA	13.5
	80%		70.0%	3.5 V	7 mA	11.5
	60%		52.0%	2.6 V	5.2 mA	8.5
	40%		35.0%	1.75 V	3.5 mA	6
4	100%	82%	90.0%	4.5 V	9 mA	14
	80%		72.0%	3.6 V	7.2 mA	11.5
	60%		(54.0%)	2.7 V	5.4 mA	9



**Figure 5-40.** Load in delta connection

Table 5-8. Load in delta connection

Number of Parallel Load Resistors	$I_{LOAD\ NOM} / I_{TYPE\ CONTROLLER}$	Current in Case of Fault	Setting Aid LED Bar Graph	Setting Aid at Actual Value Output X2.9 (0 V to 5 V)	Setting Aid at Actual Value Output X2.9 (0 mA to 20 mA)	Number of Potentiometer Turns From Left Stop
1	100%	57%	79%	3.95 V	7.9 mA	12
	80%		63%	3.15 V	6.3 mA	10
	60%		48%	2.4 V	4.8 mA	8
	40%		32%	1.6 V	3.2 mA	5.5
	20%		16%	0.8 V	1.6 mA	3.5
2	100%	76%	88%	4.4 V	8.8 mA	13.5
	80%		66%	3.3 V	6.6 mA	0.5
	60%		50%	2.5 V	5 mA	8.5
	40%		33%	1.65 V	3.3 mA	6
	20%		17%	0.85 V	1.7 mA	4
3	100%	84%	90%	4.5 V	9 mA	14
	80%		72%	3.6 V	7.2 mA	11.5
	60%		54%	2.7 V	5.4 mA	9


Thyro-A 3A With Star and Delta Loads

**Figure 5-41.** Load with common star point and without neutral conductor**Table 5-9.** Load with common star point and without neutral conductor

Number of Parallel Load Resistors	$I_{LOAD\ NOM} / I_{TYPE\ CONTROLLER}$	Current in Case of Fault	Setting Aid LED Bar Graph	Setting Aid at Actual Value Output X2.9 (0 V to 5 V)	Setting Aid at Actual Value Output X2.9 (0 mA to 20 mA)	Number of Potentiometer Turns From Left Stop
1	100%	0%	50.0%	2.5 V	5 mA	7.8

Table 5-9. Load with common star point and without neutral conductor (Continued)


Number of Parallel Load Resistors	$I_{LOAD\ NOM} / I_{TYPE\ CONTROLLER}$	Current in Case of Fault	Setting Aid LED Bar Graph	Setting Aid at Actual Value Output X2.9 (0 V to 5 V)	Setting Aid at Actual Value Output X2.9 (0 mA to 20 mA)	Number of Potentiometer Turns From Left Stop
	80%		40.0%	2 V	4 mA	6.6
	60%		30.0%	1.5 V	3 mA	5.4
	40%		20.0%	1 V	2 mA	4.2
	20%		10.0%	0.5 V	1 mA	2.9
2	100%	60%	80.0%	4 V	8 mA	11.4
	80%		64.0%	3.2 V	6.4 mA	9.5
	60%		48.0%	2.4 V	4.8 mA	7.5
	40%		32.0%	1.6 V	3.2 mA	5.7
	20%		16.0%	0.8 V	1.6 mA	3.7
3	100%	75%	87.5%	4.375 V	8.75 mA	12.3
	80%		70.0%	3.5 V	7 mA	10.3
4	100%	82%	91.0%	4.55 V	9.1 mA	12.8

**Figure 5-42.** Load in delta connection**Table 5-10.** Load in delta connection

Number of Parallel Load Resistors	$I_{LOAD\ NOM} / I_{TYPE\ CONTROLLER}$	Current in Case of Fault	Setting Aid LED Bar Graph	Setting Aid at Actual Value Output X2.9 (0 V to 5 V)	Setting Aid at Actual Value Output X2.9 (0 mA to 20 mA)	Number of Potentiometer Turns From Left Stop
1	100%	57%	78.5%	3.925 V	7.85 mA	11.3
	80%		62.8%	3.14 V	6.28 mA	9.4
	60%		47.1%	2.355 V	4.71 mA	7.5

Table 5-10. Load in delta connection (Continued)

Number of Parallel Load Resistors	$I_{LOAD\ NOM} / I_{TYPE\ CONTROLLER}$	Current in Case of Fault	Setting Aid LED Bar Graph	Setting Aid at Actual Value Output X2.9 (0 V to 5 V)	Setting Aid at Actual Value Output X2.9 (0 mA to 20 mA)	Number of Potentiometer Turns From Left Stop
	40%		31.4%	1.57 V	3.14 mA	5.6
	20%		15.7%	0.785 V	1.57 mA	3.7
2	100%	76%	88.0%	4.4 V	8.8 mA	4
	80%		70.4%	3.52 V	7.04 mA	10.3

**Figure 5-43. Other possibilities of load monitoring**

The preceding figure shows other possible load configurations:

1. Load with common star point with neutral conductor
2. Load with separate star point without neutral conductor
3. Load in open delta connection

Table 5-11. Other possibilities of load monitoring

Number of Parallel Load Resistors	$I_{LOAD\ NOM} / I_{TYPE\ CONTROLLER}$	Current in Case of Fault	Setting Aid LED Bar Graph	Setting Aid at Actual Value Output X2.9 (0 V to 5 V)	Setting Aid at Actual Value Output X2.9 (0 mA to 20 mA)	Number of Potentiometer Turns From Left Stop
1	100%	0%	50.0%	2.5 V	5 mA	7.8
	80%		40.0%	2 V	4 mA	6.7
	60%		30.0%	1.5 V	3 mA	5.4
	40%		20.0%	1 V	2 mA	4.2
	20%		10.0%	0.5 V	1 mA	3
2	100%	50%	75.0%	3.75 V	7.5 mA	10.9

Table 5-11. Other possibilities of load monitoring (Continued)

Number of Parallel Load Resistors	I _{LOAD NOM} / I _{TYPE} CONTROLLER	Current in Case of Fault	Setting Aid LED Bar Graph	Setting Aid at Actual Value Output X2.9 (0 V to 5 V)	Setting Aid at Actual Value Output X2.9 (0 mA to 20 mA)	Number of Potentiometer Turns From Left Stop
	80%		60.0%	3 V	6 mA	9
	60%		45.0%	2.25 V	4.5 mA	7.2
	40%		30.0%	1.5 V	3 mA	5.4
	20%		15.0%	0.75 V	1.5 mA	3.6
3	100%	66%	83.0%	4.15 V	8.3 mA	11.8
	80%		66.4%	3.32 V	6.64 mA	9.8
	60%		49.8%	2.49 V	4.98 mA	7.8
	40%		33.2%	1.66 V	3.32 mA	5.9
	20%		16.6%	0.83 V	1.66 mA	3.8
4	100%	75%	87.5%	4.375 V	8.75 mA	12.3
	80%		70.0%	3.5 V	7 mA	10.3
	60%		52.5%	2.625 V	5.25 mA	8.1
	40%		35.0%	1.75 V	3.5 mA	6
	20%		17.5%	0.875 V	1.75 mA	3.9
5	100%	80%	90.0%	4.5 V	9 mA	12.7

Extended Functions

Certain functions cannot be set via DIP switch or potentiometer. A bus module or a PC can be connected at the system interface X22. This makes it possible to access additional parameters, setpoints, actual values, and error messages.

Extended Operating Modes/Circuit Types

With the aid of the Thyro-Tool Pro software, it is possible to set the operating mode and circuit type independently of one another. This makes combinations possible that cannot be set with DIP switches S1.1 and S1.2.

- Operating modes
 - TAKT
 - VAR

- Load circuit types
 - Star with neutral conductor
 - Delta without neutral conductor
 - Star without neutral conductor
 - Open delta

Analog Output Averaging

In order to attain a finer line thickness for line recorders, the output signal can be smoothened, if needed, to suit the application. The default setting uses the mean of 100 mains periods.

Control Limits

For operating modes TAKT and VAR, it is possible to set control limits (end position limits).

- For TAKT:
 - Tmax Maximum switch-on period
 - Tmin Minimum switch-on period
- For VAR:
 - V_IE Front pulse end position
 - H_IE Rear pulse end position

Controller Parameters

The Thyro-A unit contains a PID controller. The parameters of the PID controller can be modified if needed to suit the application.

Parameter	Default Setting	Description
T _I	20	Controller I share
K _P	60	Controller P share
K _R	5	Controller amplification

Mains Load Optimization

The time for software synchronization can be set.

- 50 Hz ≥ Delay period after mains returns 10 ms * 100 = 1000 ms
- 60 Hz ≥ Delay period after mains returns 8.33 ms * 100 = 833 ms

(Default setting: 100)

Mains Load Optimization

Mains load optimization offers considerable benefits by reducing mains load peaks and system disturbances. Mains load optimization is possible under the following conditions:

- When more than one power controller is used
- Operating mode TAKT

The mains load is optimized by cascading the switching on of the individual devices. There are two different processes for mains load optimization, described in the following sections.

Internal Mains Load Optimization

In the operating modes QTM and TAKT, the synchronization of 2-12 controllers is possible. The operating mode QTM works in a quick half wave switch principle with a pattern of switched and blocked half waves at a set time interval < 1 second, also known as T0. In order to create a balance in the mains, from the start the individual controllers synchronize by offsetting themselves by a network period. The first of the controllers connected has the SYT input X2.7 bridged to +5 V X2.8.

The controllers which follow the first controller get their signal to X2.7 from the synchronization output (X2.6) of the previous controller. At the last controller X2.6 is not connected.

Synchronization With Optional Thyro-Power Manager Accessory

If power controllers are operating in the full wave switch mode (TAKT), then this can lead to an increased mains load through an unfavorable spread of switching on and off times. This has negative effects such as higher power loss and flicker effects. If load elements whose resistances increase over time (ageing) are used, then potentially a transformer with increased power output might need to be implemented.

All of these negative effects can be avoided or reduced to a minimum level by using the Thyro-Power Manager. The Thyro-Power Manager has a total of 10 digital outputs at terminals **X3** and **X4**. These digital outputs are set up as potential free optical coupler outputs. When optimizing the network load, the digital outputs are used as synchronization outputs (SYT) for the connected power controllers or power controller groups. All cables are to be laid shielded with the shield grounded at the output switch. For more information, see the Thyro-Power Manager operating instructions, available separately.

Characteristics:

- Minimal mains peak load and related mains feedback rates

- Changes to the setpoint and load do not automatically feed into the mains load optimization
- Can also be used in connection with already existing Advanced Energy power controllers

Basic Bus Module

The Basic Bus Module is an optional accessory for the Thyro-A series power controllers. It can control up to eight power controllers, and connects to your network using a Thyro Anybus® module, which is available for many bus protocols. The module allows the power controller to be integrated into complex installations via the field network.

With the optional digital Automatic Synchronization for Multiple power controllers feature (dASM), up to 4 Basic Bus Module accessories can be interconnected to optimize the mains load for very large installations.



Figure 5-44. Basic Bus Module

Maintenance

Fan Maintenance

The fan is subject to wear. Complete the following visual inspection every year:

- Inspect the fan blade for abrasion, deposition, and corrosion.
- Check the fan for abnormal operating noise.

The fan has an expected lifetime of $L_{10} = 37,500$ h. Depending on working conditions, a new fan should be installed after approximately five years.

Troubleshooting and Technical Support

Before requesting support, perform the recommended checks and the troubleshooting procedures in this chapter. If you are still unable to resolve the issue and resume normal operation of the equipment, contact Technical Support. You can find the contact information for “[Technical Support](#)” on page 6-5.

Troubleshooting Checklist

**DANGER:**

RISK OF DEATH OR BODILY INJURY. Follow your local jurisdiction requirements for lockout/tagout prior to connecting or disconnecting all input power sources and output connections.

**DANGER:**

RISQUE DE MORT OU DE BLESSURES. Respectez les exigences de votre juridiction locale en matière de verrouillage/étiquetage avant de connecter ou de déconnecter toutes les sources d'alimentation d'entrée et les connexions de sortie.

**DANGER:**

Personnel must receive proper training before installing or troubleshooting high-energy electrical equipment. Potentially lethal voltages could cause death, serious personal injury, or damage to the equipment. Ensure that all appropriate safety precautions are taken.

**DANGER:**

Le personnel devra être correctement formé avant de pouvoir installer ou dépanner des équipements électriques à haute énergie. Des tensions potentiellement létales peuvent entraîner le décès, des blessures ou des dommages à l'équipement. Assurez-vous de prendre toutes les précautions de sécurité appropriées.

Table 6-1. Using LED states for troubleshooting

Troubleshooting Check	Action												
Turn off AC power and make these checks.	1. Check for visible damage to the unit, cables, and connectors. 2. Ensure that all unit connectors are installed correctly and are fastened tightly. 3. Verify that no system-related circuit breakers have been tripped. 4. Ensure that ground connections are adequate and secure.												
Is the ON / READY LED lit?	If no: There could be an external line fault. 1. Make sure that there are no loose wires or unreliable connections in the AC input line. 2. Make sure that the AC disconnect switch is closed. 3. Make sure that all three phases on the AC voltage line are present and meet specifications. 4. Verify that the F1 fuse(s) are OK. 5. If this LED remains unlit, call AE Technical Support.												
Is the ON / READY LED lit in red?	If yes: The unit is on, but not ready for operation. Check the other LEDs.												
Is the LIMIT LED blinking in red?	If yes: The unit is unable to supply enough power to match the setpoint due to a limiting condition. When an internal protection limit is exceeded, the output is limited, but not shut off. 1. Disable the output. 2. Inspect and evaluate the unit load connections. Look for signs of heat stress. 3. Check the limit parameters. <table><tr><th colspan="4">Blink Number</th></tr><tr><th>1</th><th>2</th><th>3</th><th>4</th></tr><tr><td>Voltage limit</td><td>Current limit</td><td>Power limit</td><td></td></tr></table>	Blink Number				1	2	3	4	Voltage limit	Current limit	Power limit	
Blink Number													
1	2	3	4										
Voltage limit	Current limit	Power limit											

Table 6-1. Using LED states for troubleshooting (Continued)

Troubleshooting Check	Action												
Is the PULSE LOCK LED blinking in red?	If yes: The <i>PULSE LOCK</i> jumper is open, or pulse lock has been set via a bus module or the Thyro-Tool Pro software. <table><tr><th colspan="4">Blink Number</th></tr><tr><th>1</th><th>2</th><th>3</th><th>4</th></tr><tr><td>Jumper open or other condition causing pulse lock.</td><td></td><td></td><td></td></tr></table>	Blink Number				1	2	3	4	Jumper open or other condition causing pulse lock.			
Blink Number													
1	2	3	4										
Jumper open or other condition causing pulse lock.													
Is the FAULT LED lit in red?	If yes: The unit has detected a fault. This fault will generate error data that is provided through the serial port. <table><tr><th colspan="4">Blink Number</th></tr><tr><th>1</th><th>2</th><th>3</th><th>4</th></tr><tr><td>Main/Satellite fault</td><td>Flash memory fault</td><td>Temperature fault</td><td>Thyristor short circuit</td></tr></table>	Blink Number				1	2	3	4	Main/Satellite fault	Flash memory fault	Temperature fault	Thyristor short circuit
Blink Number													
1	2	3	4										
Main/Satellite fault	Flash memory fault	Temperature fault	Thyristor short circuit										
Are any LOAD FAULT LEDs lit in red?	If yes: The unit has a fault in the corresponding load. Check the load and load monitoring parameters. <table><tr><th colspan="4">Blink Number</th></tr><tr><th>1</th><th>2</th><th>3</th><th>4</th></tr><tr><td>Load voltage out of limits</td><td>Load current out of limits</td><td>Load power out of limits</td><td>Load fault</td></tr></table>	Blink Number				1	2	3	4	Load voltage out of limits	Load current out of limits	Load power out of limits	Load fault
Blink Number													
1	2	3	4										
Load voltage out of limits	Load current out of limits	Load power out of limits	Load fault										
Is the MAINS LED blinking in red?	If yes: A mains fault has occurred. <table><tr><th colspan="4">Blink Number</th></tr><tr><th>1</th><th>2</th><th>3</th><th>4</th></tr><tr><td>Overvoltage ^[1]</td><td>Undervoltage ^[1]</td><td>Phase sequence/phase fault ^[2]</td><td>Frequency/sync ^[3]</td></tr></table> ¹ Check mains voltage. Check threshold parameters using Thyro-Tool Pro software. ² Check that all phases are present. Verify right-hand phase rotation. ³ Check that all phases are present. Verify that frequency is within range and mains voltage is stable.	Blink Number				1	2	3	4	Overvoltage ^[1]	Undervoltage ^[1]	Phase sequence/phase fault ^[2]	Frequency/sync ^[3]
Blink Number													
1	2	3	4										
Overvoltage ^[1]	Undervoltage ^[1]	Phase sequence/phase fault ^[2]	Frequency/sync ^[3]										

Troubleshooting Checklist



DANGER:

RISK OF DEATH OR BODILY INJURY. Follow your local jurisdiction requirements for lockout/tagout prior to connecting or disconnecting all input power sources and output connections.



DANGER:

RISQUE DE MORT OU DE BLESSURES. Respectez les exigences de votre juridiction locale en matière de verrouillage/étiquetage avant de connecter ou de déconnecter toutes les sources d'alimentation d'entrée et les connexions de sortie.



DANGER:

Personnel must receive proper training before installing or troubleshooting high-energy electrical equipment. Potentially lethal voltages could cause death, serious personal injury, or damage to the equipment. Ensure that all appropriate safety precautions are taken.



DANGER:

Le personnel devra être correctement formé avant de pouvoir installer ou dépanner des équipements électriques à haute énergie. Des tensions potentiellement létales peuvent entraîner le décès, des blessures ou des dommages à l'équipement. Assurez-vous de prendre toutes les précautions de sécurité appropriées.

Table 6-2. Using LED states for troubleshooting

Troubleshooting Check	Action
Turn off AC power and make these checks.	1. Check for visible damage to the unit, cables, and connectors. 2. Ensure that all unit connectors are installed correctly and are fastened tightly. 3. Verify that no system-related circuit breakers have been tripped. 4. Ensure that ground connections are adequate and secure.
Is the ON / READY LED lit?	If no: There could be an external line fault. 1. Make sure that there are no loose wires or unreliable connections in the AC input line. 2. Make sure that the AC disconnect switch is closed.

Table 6-2. Using LED states for troubleshooting (Continued)

Troubleshooting Check	Action
	3. Make sure that all three phases on the AC voltage line are present and meet specifications. 4. If this LED remains unlit, call AE Technical Support.
Is the ON / READY LED lit in red?	If yes: The unit is on, but not ready for operation. Check the other LEDs.
Is the LIMIT LED blinking in red?	If yes: The unit is unable to supply enough power to match the setpoint due to a limiting condition. When an internal protection limit is exceeded, the output is limited, but not shut off. 1. Disable the output. 2. Inspect and evaluate the unit load connections. Look for signs of heat stress. 3. Check the limit parameters.
Is the PULSE LOCK LED blinking in red?	If yes: The <i>PULSE LOCK</i> jumper is open, or pulse lock has been set via a bus module or the Thyro-Tool Pro software.
Is the FAULT LED lit in red?	If yes: The unit has detected a fault. This fault will generate error data that is provided through the serial port.
Is the MAINS LED blinking in red?	If yes: A mains fault has occurred.

Technical Support

For help using or troubleshooting products, contact the Advanced Energy Technical Support Organization (TSO). Proceed as follows:

1. Make a note of the serial number (SN) and part number (PN) listed on the product label.
2. To contact the TSO by email, address the message to Technical.Support@aei.com. In the body of the email, include the serial number (SN) and part number (PN) of the product and a description of the issue.
3. To contact the TSO by telephone, dial +1.866.865.5180 (toll-free in the United States of America).
4. To contact the TSO at its business address, write to:
 AE World Headquarters
 1625 Sharp Point Drive
 Fort Collins, CO 80525 USA

Power Control Modules

For Power Control Module product support, contact by phone or email:

+49 (0) 2902 910370 10 (technical support during German business hours)

<mailto:powercontroller@aei.com>

Service, Repairs, and Upgrades

Before returning equipment for service, refurbishment, calibration, upgrade, or repair, obtain a Return Material Authorization (RMA) number. Request an RMA number using one of the methods explained in the following sections.

Obtaining an RMA Number Using an Existing MyAE Account

For customers who have a MyAE account, proceed as follows:

1. Make a note of the serial number (SN) and part number (PN) listed on the product label.
2. Go to advancedenergy.com and click **MyAE** → **MyAE Dashboard** located at the top of the screen.
3. Enter the user credentials and click **Log in**.
4. Click **Submit RMA**, **Submit Multiple RMAs**, or **Upload RMAs via CSV**.
5. Follow the instructions to complete the form(s).
6. Click the appropriate button(s) to complete the request.

Obtaining an RMA Number Using the Online Form

To obtain an RMA number using the online form, proceed as follows:

1. Make a note of the serial number (SN) and part number (PN) listed on the product label.
2. To display the RMA Request Form, go to advancedenergy.com and click **Services** located at the top of the screen.
3. On the **Services** screen, click **Submit an RMA Form**.
4. Follow the instructions to complete the form, and then click **Submit**. Required fields are marked with asterisks.

A Technical Support representative will respond with an RMA number and shipping instructions.

Obtaining an RMA Number by Email

To obtain an RMA number by email, proceed as follows:

1. Make a note of the serial number (SN) and part number (PN) listed on the product label.
2. Address an email to TECHSUPPORT@aei.com.
3. In the email subject line, include "RMA request", followed by the product serial number (SN) found on the product label. If there is prepopulated information in the subject line, replace it.
4. In the body of the email, include the serial number (SN) and part number (PN) found on the product label and a description of the reason for returning the equipment.

Obtaining an RMA Number by Telephone

To obtain an RMA by telephone, proceed as follows:

1. Make a note of the serial number (SN) and part number (PN) listed on the product label.
2. Dial +1.866.865.5180 (toll-free in the United States of America).

Index

A

authorized returns 6-6

B

basic bus module 5-44

C

certification 1-5

communication 4-16

compliance

 directives and standards 1-5

 environmental 1-7

 unit 1-4

conditions of use 1-5

configure unit

 using DIP switches 4-1

 using Thyro-Tool Pro software 4-1

conformity, letter and declaration 1-5

connections

 diagrams 5-20

connectors

 I/O and auxiliary 5-17

controls and indicators

 setpoint control 4-1

control types

 operation 5-31

cooling specifications 3-7

D

diagrams

 connection 5-20

dimensional drawings 5-1

DIP switch settings 4-4

directives and standards 1-5

E

electrical specifications 3-4

electromagnetic compatibility

 directives and standards 1-5

EMC testing 1-5

environmental specifications 3-9

extended functions

 operation 5-41

F

fan maintenance 5-44

features 2-1

G

general description 2-1

grounding 5-17

guidelines

 safety 1-2

I

icons

 in user manual 1-1

 on unit 1-2

industry guidelines, compliance with 1-5

installation

 connecting I/O 5-17

 connecting the load 5-18

 grounding 5-17

 lifting 5-16

 mounting 5-17

 preparing to install 5-1

 requirements 5-15

 spacing requirements 5-1

 unpacking 5-16

 voltage sequence control (VSC) 5-25

interlock

 overview 1-8

L

labels on unit 1-2

LEDs 4-1

 troubleshooting 6-1, 6-4

lifting 5-16

limiting conditions

 operation 1-8

load

 connecting 5-18

M

mains load optimization 5-43

maintenance

 fan 5-44

monitoring

 operation 5-33

 parallel loads 5-34

mounting 5-17

N

normal operation 5-28

O

operating modes 5-29

operation

- control types 5-31
- extended functions 5-41
- first time 5-28
- monitoring 5-33
- normal 5-28
- operating modes 5-29
- relay indicators 4-3
- setpoint 5-30

P

physical specifications 3-1

potentiometer settings 4-7

product

- certification 1-5
- compliance 1-4
- labels 1-2

R

relay indicators

- operation 4-3

S

safety

- conditions of use 1-5
- directives and standards 1-5
- guidelines 1-2

setpoint control characteristics 4-1

settings

- DIP switch 4-4
- potentiometer 4-7

software user interface 4-18

spacing requirements 5-1

specifications

- cooling 3-7
- electrical 3-4
- environmental 3-9
- physical 3-1
- type designation 3-10

standards, directives and standards 1-5

status indicators

- LEDs 4-1

- relays 4-3

support

- technical 6-5

symbols

- in user manual 1-1
- on unit 1-2

T

technical support

- contact information 6-5

Thyro-Tool Pro software

- configure unit 4-1

troubleshooting

- checklist 6-1, 6-4
- LEDs 6-1, 6-4

U

UL 1-6

unit

- compliance 1-4
 - dimensional drawings 5-1
 - features 2-1
 - general description 2-1
 - grounding 5-17
 - icons and symbols used 1-2
 - lifting 5-16
 - mounting 5-17
 - preparing to install 5-1
 - software user interface 4-18
 - unpacking 5-16
 - voltage sequence control (VSC) 5-25
- unpacking 5-16
- user manual
- alert boxes in 1-1
 - symbols and icons used 1-1

V

voltage sequence control (VSC) installation
5-25

W

warranty

- authorized returns 6-6